

SCHOOL:	Cardiff High School (8903)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Charlestown
LOCAL GOVERNMENT AREA:	Lake Macquarie

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Music Learning Space - (53.33 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0005 - Music Learning Space - (64.57 SQM) - Teaching Space: 1	● Student Space (53)	
B00A - R0006 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0007 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0008 - General Learning Space - (53.78 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0009 - Movement - (31.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - General Learning Space - (53.4 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R0011 - General Learning Space - (53.4 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R0012 - Staff Study - (13.97 SQM)	● Office (3)	
B00A - R0013 - Staff Study - (52.97 SQM)	● Office (13)	
B00A - R0015 - Staff Study - (26.28 SQM)	● Office (6)	
B00A - R0019 - Darkroom Space - (12.49 SQM)	● Office (3)	
B00A - R0020 - Art Learning Space - (72.73 SQM) - Teaching Space: 1	● Student Space (53)	
B00A - R0024 - Art Learning Space - (63.3 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0025 - Art Learning Space - (53.48 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0026 - Staff Study - (26.3 SQM)	● Office (6)	
B00A - R0027 - Movement - (63.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (145.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (66.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - General Learning Space - (53.41 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1005 - General Learning Space - (53.41 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1006 - General Learning Space - (67.27 SQM) - Teaching Space: 1	● Student Space (53)	
B00A - R1007 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1008 - General Learning Space - (53.77 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1009 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R1010 - General Learning Space - (53.03 SQM) - Teaching Space: 1	● Student Space (64)	
B00A - R1011 - Staff Study - (14.26 SQM)	● Office (3)	
B00A - R1012 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (64)	
B00A - R1013 - Staff Study - (35.22 SQM)	● Office (8)	
B00A - R1018 - Computer Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1019 - Computer Learning Space - (52.35 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1021 - Staff Study - (47.76 SQM)	● Office (11)	
B00A - R1023 - Movement - (198.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Computer Room - (86.12 SQM)	● Student Space (63)	
B00A - R1027 - Staff Kitchen - (6.2 SQM)	● Office (1)	
B00A - R1030 - Movement - (206.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Movement - (20.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Movement - (46.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R9006 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R9007 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R9008 - Staff Study - (13.16 SQM)	● Office (3)	
B00A - R9009 - General Learning Space - (51.66 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R9011 - Staff Study - (26.01 SQM)	● Office (6)	
B00A - R9016 - Seminar/Technology Space - (12.08 SQM)	● Office (3)	
B00A - R9017 - Food Technology L.S. - (92.08 SQM) - Teaching Space: 1	● Student Space (79)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R9019 - Food Technology L.S. - (66.11 SQM) - Teaching Space: 1	● Student Space (46)	
B00A - R9023 - Materials Technology L.S. - (64.83 SQM) - Teaching Space: 1	● Student Space (46)	
B00A - R9024 - Movement - (205.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R9032 - Movement - (207.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Ancillary Staff - (21.76 SQM)	○ Office (5)	
B00B - R0002 - Principal Office - (18.76 SQM)	○ Office (4)	
B00B - R0021 - Public Reception - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Student Reception - (24.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Deputy Principal Office - (12.56 SQM)	○ Office (3)	
B00B - R0026 - Student Waiting - (12.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Deputy Principal Office - (13.02 SQM)	○ Office (3)	
B00B - R0028 - Interview/Meeting - (35.12 SQM)	○ Office (8)	
B00B - R0029 - Interview/Meeting - (11.7 SQM)	○ Office (2)	
B00B - R0030 - Staff Study - (13.95 SQM)	○ Office (3)	
B00B - R0032 - Movement - (57.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Clinic - (13.7 SQM)	○ Office (3)	
B00B - R0035 - Staff Kitchen - (8.19 SQM)	○ Office (2)	
B00B - R0036 - Staff Lounge - (11.86 SQM)	○ Office (2)	
B00B - R0037 - Administration - Clerical - (67.9 SQM)	○ Office (16)	
B00B - R0038 - Principal Office - (19.92 SQM)	○ Office (4)	
B00B - R0039 - Interview/Meeting - (12.61 SQM)	○ Office (3)	
B00C - R0009 - Student Canteen - (48.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Practical Activities - (172.88 SQM)	● Student Space (80)	
B00D - R0001 - Seminar - (21.09 SQM)	○ Office (5)	
B00D - R0002 - Seminar - (13.11 SQM)	○ Office (3)	
B00D - R0008 - Entry - (16.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Workroom - (40.47 SQM)	○ Office (10)	
B00D - R0011 - Audio Visual Workroom - (35.3 SQM)	● Student Space (33)	
B00D - R0015 - Main Area - (412.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (8.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (95.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Laboratory L.S. - (86.02 SQM) - Teaching Space: 1	● Student Space (170)	
B00E - R0007 - Preparation - (39.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Laboratory L.S. - (86.01 SQM) - Teaching Space: 1	● Student Space (141)	
B00E - R0011 - Senior Study - (52.97 SQM)	○ Office (13)	
B00E - R0013 - Movement - (25.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Staff Study - (32.95 SQM)	○ Office (8)	
B00E - R0018 - Staff Kitchen - (5.6 SQM)	○ Office (1)	
B00E - R0020 - Study Space - (11.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Movement - (12.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Movement - (89.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Laboratory L.S. - (88.16 SQM) - Teaching Space: 1	● Student Space (82)	
B00E - R1006 - Preparation - (38.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Laboratory L.S. - (85.87 SQM) - Teaching Space: 1	● Student Space (157)	
B00E - R1011 - Movement - (16.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Staff Study - (12.01 SQM)	○ Office (3)	
B00E - R1013 - Movement - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1015 - Staff Study - (34.5 SQM)	○ Office (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1018 - Staff Lounge - (107.23 SQM)	Office (26)	
B00F - R0001 - General Learning Space - (65.72 SQM) - Teaching Space: 1	Student Space (94)	
B00F - R0002 - Movement - (52.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Staff Study - (25.86 SQM)	Office (6)	
B00F - R0009 - Design L.S. - (52.82 SQM) - Teaching Space: 1	Student Space (47)	
B00F - R0010 - Welding Area - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Seminar/Technology Space - (10.55 SQM)	Office (2)	
B00F - R0012 - Materials Technology L.S. - (72.07 SQM) - Teaching Space: 1	Student Space (94)	
B00F - R0014 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Design L.S. - (59.23 SQM) - Teaching Space: 1	Student Space (70)	
B00F - R1004 - Movement - (7.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Movement - (48.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R1006 - Materials Technology L.S. - (79.04 SQM) - Teaching Space: 1	Student Space (70)	
B00F - R1009 - Materials Technology L.S. - (83.41 SQM) - Teaching Space: 1	Student Space (117)	
B00G - R0001 - Performance Workspace - (73.75 SQM) - Teaching Space: 1	Student Space (34)	
B00G - R0003 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Staff Kitchen - (20.48 SQM)	Office (5)	
B00G - R1003 - Multi-Purpose Space - (388.76 SQM)	Student Space (411)	
B00G - R1004 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Stage - (99.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R1006 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Movement - (46.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R1012 - Movement - (32.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R1014 - Movement - (77.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R9003 - General Assistants - (13.01 SQM)	Office (3)	
OS 522 14805 - OS 522 14805 - Staff Study - (38 SQM)	Office (9)	
OS 600 15268 - OS 600 15268 - Learning Unit - Small - (57 SQM)	Student Space (101)	
OS 601 14789 - OS 601 14789 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (101)	
OS 601 15320 - OS 601 15320 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (94)	
OS 601 19728 - OS 601 19728 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (82)	
OS 601 19733 - OS 601 19733 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (82)	
OS 621 10728 - OS 621 10728 - Learning Unit Single - PWD - (95 SQM)	Student Space (82)	
OS 621 19538 - OS 621 19538 - Learning Unit Single - PWD - (95 SQM)	Student Space (82)	