

SCHOOL:	Deniliquin South Public School (4112)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Edward River

4112 - Deniliquin South Public School
Site Plan (10956)



1:1,397

Printed: 21-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.2 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0005 - Home Base - (53.35 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0008 - Staff Room Annexe - (18.46 SQM)	○ Office (4)	
B00A - R0009 - Practical Activities - 1hb - (45.55 SQM)	● Student Space (21)	
B00A - R0013 - Home Base - (52.1 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0014 - Home Base - (79.76 SQM) - Teaching Space: 1	● Student Space (44)	
B00B - R0002 - Home Base - (53.64 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0003 - Home Base - (53.34 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0002 - Entry Vestibule - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Staff Room Annexe - (12.64 SQM)	○ Office (3)	
B00C - R0007 - Home Base - (53.12 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0008 - Home Base - (53.41 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0009 - Staff Room Annexe - (9.36 SQM)	○ Office (2)	
B00C - R0010 - Staff Room Annexe - (12.73 SQM)	○ Office (3)	
B00C - R0011 - Home Base - (53.35 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0012 - Home Base - (53.49 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0001 - Staff Room - (45.38 SQM)	○ Office (11)	
B00D - R0008 - Principal - (16.75 SQM)	○ Office (4)	
B00D - R0009 - Duplicating Workroom - (19.87 SQM)	○ Office (4)	
B00D - R0010 - Movement - (57.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Clerical Office - (17.65 SQM)	○ Office (4)	
B00D - R0013 - Sick Bay - (8.59 SQM)	● Student Space (3)	
B00D - R0015 - Deputy Principal - (13.12 SQM)	○ Office (3)	
B00D - R0016 - Interview - (13.15 SQM)	○ Office (3)	
B00D - R0017 - Interview - (13.15 SQM)	○ Office (3)	
B00D - R0018 - Staff Room Annexe - (19.65 SQM)	○ Office (4)	
B00E - R0002 - Home Base - (56.55 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0006 - Home Base - (56.38 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0009 - Home Base - (56.55 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0001 - Communal Space - (237.63 SQM)	● Student Space (110)	
OS 534 12378 - OS 534 12378 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 801 17748 - OS 801 17748 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.