

<b>SCHOOL:</b>	<b>Evans River Community School (1886)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Clarence</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Richmond Valley</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.














Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0005 - Home Base - (59.44 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0007 - Withdrawal Space - 1hb - (11.67 SQM)	● Student Space (5)	
B00I - R0009 - Home Base - (59.05 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0013 - Home Base - (59.52 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0015 - Withdrawal Space - 1hb - (11.63 SQM)	● Student Space (5)	
B00I - R0017 - Home Base - (59.44 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0021 - Home Base - (59.05 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0023 - Withdrawal Space - 1hb - (11.66 SQM)	● Student Space (5)	
B00I - R0025 - Home Base - (59.05 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0027 - Practical Activities - 1hb - (15.55 SQM)	● Student Space (7)	
B00I - R0028 - Practical Activities - 1hb - (15.58 SQM)	● Student Space (7)	
B00I - R0029 - Practical Activities - 1hb - (15.51 SQM)	● Student Space (7)	
B00I - R0030 - Practical Activities - 1hb - (15.55 SQM)	● Student Space (7)	
B00I - R0031 - Practical Activities - 1hb - (15.51 SQM)	● Student Space (7)	
B00I - R0032 - Practical Activities - 1hb - (15.55 SQM)	● Student Space (7)	
B00J - R0001 - Gymnasium - (970.7 SQM)	● Student Space (450)	
B00J - R0002 - Canteen - (11.12 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Communal Space - (77.14 SQM)	● Student Space (35)	
B00J - R0016 - Movement - (21.3 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Movement - (18.78 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Interview - (13.58 SQM)	● Office (3)	
B00L - R0007 - General Learning Space - M - (60.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0009 - Withdrawal - M - (11.3 SQM)	● Student Space (5)	
B00L - R0011 - General Learning Space - M - (60.13 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0015 - Home Base - (60.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0017 - Withdrawal Space - 1hb - (11.23 SQM)	● Student Space (5)	
B00L - R0019 - Home Base - (60.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0021 - Practical Activities - M - 1hb - (15.17 SQM)	● Student Space (7)	
B00L - R0022 - Practical Activities - M - 1hb - (14.99 SQM)	● Student Space (6)	
B00L - R0023 - Practical Activities - 1hb - (14.96 SQM)	● Student Space (6)	
B00L - R0024 - Practical Activities - 1hb - (14.9 SQM)	● Student Space (6)	
B00M - R0005 - Seminar/Technology Space - (32.34 SQM)	● Office (8)	
B00M - R0009 - Seminar/Study - (12.97 SQM)	● Office (3)	
B00M - R0010 - Seminar/Study - (12.86 SQM)	● Office (3)	
B00M - R0011 - Reading Area - (314.83 SQM)	● Student Space (146)	
B00M - R0013 - Seminar/Study - (51.38 SQM)	● Office (12)	
B00N - R0001 - Canteen - (45.22 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - Communal Space - (193.82 SQM)	● Student Space (89)	
B00N - R0015 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00N - R0016 - Raised Platform - (50.56 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Movement - (13.83 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Movement - (57.76 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Interview - (12.9 SQM)	● Office (3)	
B00O - R0003 - Deputy Principal - (16.46 SQM)	● Office (4)	
B00O - R0004 - Clinic-Waiting - (17.04 SQM)	● Office (4)	
B00O - R0005 - Interview - (13.03 SQM)	● Office (3)	
B00O - R0006 - Deputy Principal - (12.91 SQM)	● Office (3)	
B00O - R0018 - Duplicating Workroom - (18.65 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00O - R0019 - Pupil Entry - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00O - R0020 - Clerical Office - (33.4 SQM)	Office (8)	
B00O - R0021 - Public Entry - (14.66 SQM)	Not Applicable	Circulation or storage space.
B00O - R0022 - Interview - (15.86 SQM)	Office (3)	
B00O - R0023 - Principal - (19.01 SQM)	Office (4)	
B00O - R0024 - Interview - (14.89 SQM)	Office (3)	
B00O - R0030 - Clerical Office - (11.01 SQM)	Office (2)	
B00P - R0001 - Laboratory L.S. - (92.31 SQM) - Teaching Space: 1	Student Space (223)	
B00P - R0003 - Preparation - (51.18 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Growing/Breeding - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00P - R0008 - Laboratory L.S. - (92.3 SQM) - Teaching Space: 1	Student Space (223)	
B00P - R0009 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00P - R0014 - Staff Room Annexe - (197.13 SQM)	Office (49)	
B00P - R0015 - Teachers Aides - (12.11 SQM)	Office (3)	
B00P - R0016 - Practical Activities - S - 1hb - (19.3 SQM)	Student Space (74)	
B00P - R0017 - Home Base - S - (41.24 SQM) - Teaching Space: 1	Student Space (75)	
B00P - R1001 - Computer Learning Space - (63.47 SQM) - Teaching Space: 1	Student Space (223)	
B00P - R1005 - General Learning Space - (64.45 SQM) - Teaching Space: 1	Student Space (186)	
B00P - R1009 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00P - R1014 - Staff Room - (78.57 SQM)	Office (19)	
B00P - R1016 - General Learning Space - (61.81 SQM) - Teaching Space: 1	Student Space (186)	
B00P - R1017 - Withdrawal Space - 1hb - (26.24 SQM)	Student Space (111)	
B00P - R1020 - Interview - (16.99 SQM)	Office (4)	
B00P - R1021 - General Learning Space - (61.81 SQM) - Teaching Space: 1	Student Space (186)	
B00P - R1022 - General Learning Space - (63.65 SQM) - Teaching Space: 1	Student Space (186)	
B00P - R1030 - General Learning Space - (94.18 SQM) - Teaching Space: 1	Student Space (186)	
B00Q - R0003 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0008 - Darkroom Space - (31.31 SQM)	Office (7)	
B00Q - R0012 - Art Learning Space - (63.28 SQM) - Teaching Space: 1	Student Space (186)	
B00Q - R0014 - Workshop - (51.47 SQM)	Student Space (148)	
B00Q - R0016 - Art Learning Space - (59.35 SQM) - Teaching Space: 1	Student Space (186)	
B00Q - R1001 - Music Learning Space - (82.5 SQM) - Teaching Space: 1	Student Space (297)	
B00Q - R1003 - Practice/Seminar - (23.36 SQM)	Student Space (74)	
B00Q - R1005 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1010 - General Learning Space - (59.77 SQM) - Teaching Space: 1	Student Space (223)	
B00Q - R1011 - Withdrawal Space - 1hb - (13.49 SQM)	Student Space (37)	
B00Q - R1013 - General Learning Space - (64.88 SQM) - Teaching Space: 1	Student Space (223)	
B00Q - R1014 - General Learning Space - (62.55 SQM) - Teaching Space: 1	Student Space (223)	
B00Q - R1016 - General Learning Space - (61.96 SQM) - Teaching Space: 1	Student Space (186)	
B00R - R0007 - Materials Technology L.S. - (179.86 SQM) - Teaching Space: 1	Student Space (223)	
B00R - R0008 - Metal Technology Bay - (34.88 SQM)	Not Applicable	Circulation or storage space.
B00R - R0010 - Workshop Area - (56.07 SQM)	Student Space (26)	
B00R - R0011 - Welding Area - (12.25 SQM)	Not Applicable	Circulation or storage space.
B00R - R0013 - Wood Technology Bay - (50.12 SQM)	Not Applicable	Circulation or storage space.
B00R - R0021 - Welding Area - (16.36 SQM)	Not Applicable	Circulation or storage space.
B00R - R1005 - Design/Technology L.S. - (93.49 SQM) - Teaching Space: 1	Student Space (260)	
B00R - R1006 - Seminar/Technology Space - (18.96 SQM)	Office (4)	
B00R - R1007 - Interview - (14.69 SQM)	Office (3)	
B00R - R1009 - Design/Technology L.S. - (101.66 SQM) - Teaching Space: 1	Student Space (260)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00R - R1022 - Kitchen - Type 1 - (120.87 SQM)	 Student Space (223)	
B00S - R0002 - Outdoor Learning Area - (78.13 SQM)	Not Applicable	Circulation or storage space.
B00V - R0004 - Clerical Office - (5.91 SQM)	 Office (1)	
B00V - R0006 - Clerical Office - (13.25 SQM)	 Office (3)	
B00V - R0007 - Seminar - (13.63 SQM)	 Office (3)	
B00V - R0008 - Seminar - (12.88 SQM)	 Office (3)	
B00V - R0009 - Seminar - (14.13 SQM)	 Office (3)	
B00V - R0010 - Special Programs Room - (60.31 SQM)	 Student Space (148)	
B00V - R0011 - General Learning Space - (56.52 SQM) - Teaching Space: 1	 Student Space (186)	
B00V - R1004 - General Learning Space - (59.96 SQM) - Teaching Space: 1	 Student Space (223)	
B00V - R1005 - General Learning Space - (59.99 SQM) - Teaching Space: 1	 Student Space (149)	
B00V - R1006 - General Learning Space - (59.9 SQM) - Teaching Space: 1	 Student Space (186)	
OS 601 13066 - OS 601 13066 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (705)	
OS 603 13464 - OS 603 13464 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (260)	