

VENTILATION AUDIT REPORT Version 2

SCHOOL:	Hamilton North Public School (3897)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Newcastle
LOCAL GOVERNMENT AREA:	Newcastle

3897 - Hamilton North Public School
Site Plan (10405)



1:620

Printed: 21-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (94.59 SQM) - Teaching Space: 1	● Student Space (112)	
B00B - R0004 - Reading Area - (105.27 SQM)	● Student Space (48)	
B00C - R0002 - Home Base - (47.06 SQM) - Teaching Space: 1	● Student Space (65)	
B00C - R0003 - Canteen - (17.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (53.14 SQM) - Teaching Space: 1	● Student Space (84)	
B00E - R0002 - Communal Space - (72.33 SQM)	● Student Space (33)	
B00G - R0001 - Home Base - (52.13 SQM) - Teaching Space: 1	● Student Space (84)	
B00G - R0003 - Duplicating Workroom - (15.69 SQM)	● Office (3)	
B00G - R0004 - Clerical Office/Workroom - (7.06 SQM)	● Office (1)	
B00G - R0009 - Staff Room - (26.67 SQM)	● Office (6)	
B00G - R0010 - Clerical Office/Workroom - (24.24 SQM)	● Office (6)	
B00G - R0011 - Entry Vestibule - (8.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Principal - (17.27 SQM)	● Office (4)	
B00H - R0002 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	
B00H - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	● Student Space (103)	
B00H - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	● Student Space (4)	
B00H - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	● Student Space (103)	
B00H - R0008 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	
B00I - R0002 - Home Base - (142.24 SQM) - Teaching Space: 1	● Student Space (93)	