

SCHOOL:	Lake Cathie Public School (4654)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical/Printing - (53.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (23.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Principal - (16.43 SQM)	Office (4)	
B00A - R0004 - Sick Bay - (9.45 SQM)	Student Space (9)	
B00A - R0005 - Deputy Principal - Type 1 - (13.49 SQM)	Office (3)	
B00A - R0006 - Interview - (12.42 SQM)	Office (3)	
B00A - R0007 - Interview - (16.43 SQM)	Office (4)	
B00A - R0013 - Staff Room - (59.19 SQM)	Office (14)	
B00A - R0016 - Staff Kitchen - (8.51 SQM)	Office (2)	
B00A - R0018 - Movement - (37.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (198.18 SQM)	Student Space (46)	
B00B - R0005 - Special Programs Room - (31.33 SQM)	Student Space (14)	
B00C - R0011 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Raised Platform - (61.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Communal Space - (149.22 SQM)	Student Space (176)	
B00C - R0021 - Special Programs Room - (37.8 SQM)	Student Space (17)	
B00C - R0022 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Reading Area - (63.9 SQM)	Student Space (46)	
B00D - R0001 - Canteen - (26.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Withdrawal Space - 2hb - (15.73 SQM)	Student Space (7)	
B00E - R0002 - Practical Activities - (16.97 SQM)	Student Space (7)	
B00E - R0003 - Outdoor Learning Area - (64.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Withdrawal Space - 1hb - (12.36 SQM)	Student Space (5)	
B00E - R0005 - Outdoor Learning Area - (30.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (63.93 SQM) - Teaching Space: 1	Student Space (56)	
B00E - R0008 - Collaboration Space - (99.57 SQM)	Student Space (46)	
B00E - R0009 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (45)	
B00E - R0010 - Outdoor Learning Area - (29.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Withdrawal Space - 1hb - (12.4 SQM)	Student Space (5)	
B00E - R0012 - Home Base - (64.62 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0013 - Practical Activities - (16.72 SQM)	Student Space (7)	
B00E - R0015 - Withdrawal Space - 1hb - (12.49 SQM)	Student Space (5)	
B00F - R0001 - Withdrawal Space - 1hb - (12.41 SQM)	Student Space (5)	
B00F - R0002 - Practical Activities - (16.24 SQM)	Student Space (7)	
B00F - R0004 - Home Base - (64.57 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0005 - Withdrawal Space - 1hb - (12.81 SQM)	Student Space (5)	
B00F - R0006 - Outdoor Learning Area - (29.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (64.12 SQM) - Teaching Space: 1	Student Space (45)	
B00F - R0009 - Collaboration Space - (99.84 SQM)	Student Space (46)	
B00F - R0010 - Home Base - (64.01 SQM) - Teaching Space: 1	Student Space (45)	
B00F - R0011 - Outdoor Learning Area - (28.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Withdrawal Space - 1hb - (12.77 SQM)	Student Space (5)	
B00F - R0013 - Home Base - (64.58 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0014 - Practical Activities - (16.34 SQM)	Student Space (7)	
B00F - R0015 - Withdrawal Space - 1hb - (15.74 SQM)	Student Space (7)	
B00G - R0001 - Withdrawal Space - 1hb - (12.21 SQM)	Student Space (5)	
B00G - R0002 - Practical Activities - (17.31 SQM)	Student Space (8)	
B00G - R0004 - Home Base - (67.48 SQM) - Teaching Space: 1	Student Space (31)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Withdrawal Space - 1hb - (14.05 SQM)	● Student Space (6)	
B00G - R0006 - Outdoor Learning Area - (29.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (65.3 SQM) - Teaching Space: 1	● Student Space (47)	
B00G - R0009 - Collaboration Space - (98.96 SQM)	● Student Space (45)	
B00G - R0010 - Home Base - (64.47 SQM) - Teaching Space: 1	● Student Space (47)	
B00G - R0011 - Outdoor Learning Area - (29.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Withdrawal Space - 1hb - (14.2 SQM)	● Student Space (6)	
B00G - R0013 - Home Base - (69.69 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0014 - Practical Activities - (17.35 SQM)	● Student Space (8)	
B00G - R0015 - Withdrawal Space - 1hb - (15.45 SQM)	● Student Space (7)	
B00G - R0016 - Outdoor Learning Area - (48.71 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Withdrawal Space - 1hb - (12.31 SQM)	● Student Space (5)	
B00G - R1002 - Practical Activities - (18.21 SQM)	● Student Space (8)	
B00G - R1004 - Home Base - (69.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R1005 - Withdrawal Space - 1hb - (14.38 SQM)	● Student Space (6)	
B00G - R1006 - Outdoor Learning Area - (32.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Home Base - (68.93 SQM) - Teaching Space: 1	● Student Space (47)	
B00G - R1008 - Collaboration Space - (86.59 SQM)	● Student Space (40)	
B00G - R1009 - Home Base - (68.61 SQM) - Teaching Space: 1	● Student Space (47)	
B00G - R1010 - Outdoor Learning Area - (32.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Withdrawal Space - 1hb - (14.1 SQM)	● Student Space (6)	
B00G - R1012 - Home Base - (69.33 SQM) - Teaching Space: 1	● Student Space (33)	
B00G - R1013 - Practical Activities - (18.39 SQM)	● Student Space (8)	
B00G - R1014 - Withdrawal Space - 1hb - (15.39 SQM)	● Student Space (7)	
B00G - R1015 - Outdoor Learning Area - (48.71 SQM)	Not Applicable	Circulation or storage space.
NS 100 11968 - NS 100 11968 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 12377 - NS 100 12377 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 12432 - NS 100 12432 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 15487 - NS 100 15487 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 15887 - NS 100 15887 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16170 - NS 100 16170 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16821 - NS 100 16821 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16904 - NS 100 16904 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16905 - NS 100 16905 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16906 - NS 100 16906 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16907 - NS 100 16907 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16908 - NS 100 16908 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 606 19263 - OS 606 19263 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19270 - OS 606 19270 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (56)	
OS 606 19581 - OS 606 19581 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	