


SCHOOL:	Lakelands Public School (4266)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Shellharbour
LOCAL GOVERNMENT AREA:	Wollongong



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (73)	
B00A - R0012 - Staff Room Annexe - (17.26 SQM)	● Office (4)	
B00A - R0017 - Movement - (29.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Home Base - (58.47 SQM) - Teaching Space: 1	● Student Space (73)	
B00A - R0028 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R0036 - Home Base - (58.38 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R0038 - Practical Activities - 1hb - (13.24 SQM)	● Student Space (6)	
B00A - R0040 - Home Base - (77.88 SQM) - Teaching Space: 1	● Student Space (100)	
B00A - R0041 - Practical Activities - 1hb - (14.12 SQM)	● Student Space (6)	
B00A - R0044 - Home Base - (56.97 SQM) - Teaching Space: 1	● Student Space (73)	
B00A - R0045 - Withdrawal Space - 2hb - (10.55 SQM)	● Student Space (4)	
B00A - R0046 - Practical Activities - 2hb - (6.37 SQM)	● Student Space (2)	
B00A - R0047 - Practical Activities - 2hb - (18.72 SQM)	● Student Space (8)	
B00B - R0001 - Home Base - (58.62 SQM) - Teaching Space: 1	● Student Space (73)	
B00B - R0005 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (58.61 SQM) - Teaching Space: 1	● Student Space (73)	
B00C - R0001 - Home Base - (68.93 SQM) - Teaching Space: 1	● Student Space (154)	
B00C - R0012 - Withdrawal Space - 1hb - (16.19 SQM)	● Student Space (7)	
B00C - R0015 - Home Base - (56.96 SQM) - Teaching Space: 1	● Student Space (63)	
B00C - R0023 - Home Base - (58.62 SQM) - Teaching Space: 1	● Student Space (91)	
B00C - R0026 - Movement - (9.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Practical Activities - 2hb - (17.92 SQM)	● Student Space (8)	
B00C - R1005 - Reading Area - (56.64 SQM)	● Student Space (26)	
B00C - R1006 - Reading Area - (67.56 SQM)	● Student Space (31)	
B00D - R0001 - Home Base - (59.27 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0004 - Movement - (20.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Staff Room Annexe - (9.8 SQM)	● Office (2)	
B00D - R0011 - Deputy Principal - (9.77 SQM)	● Office (2)	
B00D - R0014 - Movement - (37.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Entry Vestibule - (16.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Clerical Office - (7.76 SQM)	● Office (1)	
B00D - R0018 - Clerical Office/Workroom - (13.81 SQM)	● Office (3)	
B00D - R0019 - Principal - (18.32 SQM)	● Office (4)	
B00D - R0024 - Clerical Office/Workroom - (38.9 SQM)	● Office (9)	
B00D - R0025 - Sick Bay - (9.65 SQM)	● Student Space (4)	
B00D - R0028 - Movement - (36.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Movement - (20.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Home Base - (57.61 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R0034 - Home Base - (57.62 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0039 - Staff Room - (47.88 SQM)	● Office (11)	
B00D - R0040 - Staff Kitchen - (8.66 SQM)	● Office (2)	
B00D - R0041 - Practical Activities - 2hb - (17.65 SQM)	● Student Space (8)	
B00D - R1001 - Home Base - (57.68 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R1006 - Home Base - (57.23 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R1010 - Practical Activities - 2hb - (35.37 SQM)	● Student Space (16)	
B00D - R9001 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R9004 - Home Base - (57.45 SQM) - Teaching Space: 1	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R9007 - Movement - (18.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R9014 - Movement - (15.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R9018 - Practical Activities - 2hb - (18.77 SQM)	● Student Space (8)	
B00H - R0003 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Raised Platform - (52.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Communal Space - (186.24 SQM)	● Student Space (86)	
B00H - R0014 - Canteen - (43.48 SQM)	Not Applicable	Circulation or storage space.