

SCHOOL:	Monaro High School (8196)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Snowy Monaro

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.
















Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0001 - Leading Teacher - (8 SQM)	Office (2)	
B00B - R0003 - Materials Technology L.S. - (79.21 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0004 - Staff Study - (9.61 SQM)	Office (2)	
B00B - R0012 - Staff Study - (23.89 SQM)	Office (5)	
B00B - R0017 - General Learning Space - (69.12 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0018 - General Learning Space - (92.6 SQM) - Teaching Space: 1	Student Space (71)	
B00B - R0019 - Growing/Breeding - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Preparation - (28.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - General Learning Space - (92.59 SQM) - Teaching Space: 1	Student Space (57)	
B00B - R0024 - General Learning Space - (52.23 SQM) - Teaching Space: 1	Student Space (51)	
B00B - R0025 - Movement - (115.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Movement - (5.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (21.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (12.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Materials Technology L.S. - (118.05 SQM) - Teaching Space: 1	Student Space (54)	
B00B - R0048 - Metal Technology Bay - (14.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0049 - Wood Technology Bay - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (52.16 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1002 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1003 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1004 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1006 - General Learning Space - (52.23 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1007 - Staff Study - (25.57 SQM)	Office (6)	
B00B - R1010 - General Learning Space - (53.76 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1013 - General Learning Space - (52.09 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1014 - General Learning Space - (52.16 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R1016 - General Learning Space - (52.23 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1017 - Movement - (9.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Leading Teacher - (6 SQM)	Office (1)	
B00B - R1019 - Staff Study - (25.39 SQM)	Office (6)	
B00B - R1021 - Computer Learning Space - (50.79 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1023 - Movement - (102 SQM)	Not Applicable	Circulation or storage space.
B00B - R1025 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1027 - General Learning Space - (39.35 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R1028 - Movement - (64.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1030 - Movement - (85.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R1035 - Performance Workspace - (79.6 SQM) - Teaching Space: 1	Student Space (36)	
B00C - M1001 - Senior Study - (119.65 SQM)	Office (29)	
B00C - M1003 - Study Space - (18.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Staff Study - (91.39 SQM)	Office (22)	
B00C - R0020 - Interview/Meeting - (15.41 SQM)	Office (3)	
B00C - R0022 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Staff Lounge - (46.45 SQM)	Office (11)	
B00C - R0024 - Staff Kitchen - (39.87 SQM)	Office (9)	
B00C - R0025 - Staff Study - (122.33 SQM)	Office (30)	
B00C - R0026 - Interview/Meeting - (16.23 SQM)	Office (4)	
B00C - R0027 - Staff Study - (47.78 SQM)	Office (11)	
B00C - R0028 - Movement - (73.23 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1001 - Audio Visual Workroom - (47.93 SQM)	● Student Space (22)	
B00C - R1003 - Movement - (46.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Main Area - (364.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Seminar - (12.02 SQM)	● Office (3)	
B00C - R1007 - Seminar - (12.61 SQM)	● Office (3)	
B00C - R1010 - Seminar - (12.6 SQM)	● Office (3)	
B00C - R1011 - Seminar - (12.09 SQM)	● Office (3)	
B00C - R1013 - Computer Learning Space - (37.16 SQM) - Teaching Space: 1	● Student Space (17)	
B00D - R0008 - Movement - (15.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - General Learning Space - (63.17 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0010 - Kitchen - Type 1 - (37.54 SQM)	● Student Space (17)	
B00D - R0011 - Movement - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Interview/Office - Type 1 - (12.95 SQM)	● Office (3)	
B00D - R0014 - Commonroom - (9.17 SQM)	● Office (2)	
B00D - R0015 - General Learning Space - (55.58 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0017 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Multi-Purpose Space - (328.35 SQM)	● Student Space (152)	
B00H - R0003 - Movement - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Stage - (78.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Staff Kitchen - (18.27 SQM)	● Office (4)	
B00H - R0012 - Movement - (23.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R9006 - Student Canteen - (42.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R9007 - Staff Kitchen - (26.71 SQM)	● Office (6)	
B00H - R9009 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R9013 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R9015 - General Assistants - (11.21 SQM)	● Office (2)	
B00K - R0001 - Laboratory L.S. - (65.39 SQM) - Teaching Space: 1	● Student Space (202)	
B00K - R0002 - Movement - (104.25 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Laboratory L.S. - (82.44 SQM) - Teaching Space: 1	● Student Space (76)	
B00K - R0009 - Laboratory L.S. - (82.47 SQM) - Teaching Space: 1	● Student Space (42)	
B00K - R0014 - Preparation - Science - (18.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Preparation - Science - (37.32 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Music Learning Space - (67.12 SQM) - Teaching Space: 1	● Student Space (101)	
B00K - R1002 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00K - R1006 - Staff Study - (25.01 SQM)	● Office (6)	
B00K - R1007 - Music Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (50)	
B00K - R1010 - Art Learning Space - (58.49 SQM) - Teaching Space: 1	● Student Space (50)	
B00K - R1011 - Art Learning Space - (53.18 SQM) - Teaching Space: 1	● Student Space (50)	
B00K - R1018 - Movement - (54.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R1019 - Movement - (26.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R9001 - Performance Workspace - (67.64 SQM) - Teaching Space: 1	● Student Space (31)	
B00K - R9003 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R9006 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00K - R9007 - Darkroom Space - (36.61 SQM)	● Office (9)	
B0D1 - R0002 - Multi Media Studio - (11.43 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0003 - Multi Media Studio - (17.54 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0004 - Multi Media Studio - (16.45 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0006 - General Learning Space - Type 1 - (67.99 SQM) - Teaching Space: 1	● Student Space (31)	
B0D1 - R0007 - Seminar - Type 1 - (33.26 SQM)	● Office (8)	
B0D1 - R0013 - Movement - (12.26 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0014 - General Learning Space - (60.26 SQM) - Teaching Space: 1	● Student Space (57)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOD1 - R0015 - Shared Study Space - (42.45 SQM)	 Office (10)	
BOD1 - R0016 - Practical Activities - (11.78 SQM)	 Student Space (5)	
BOD1 - R0017 - General Learning Space - (60.29 SQM) - Teaching Space: 1	 Student Space (57)	
BOD1 - R0018 - Multi-Purpose Space - (78.92 SQM)	 Student Space (36)	
BOD1 - R0019 - Multi Media Workshop - (99.8 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0020 - Kitchen - Type 1 - (14.46 SQM)	 Student Space (6)	
BOD1 - R0021 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0022 - Movement - (24.17 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0023 - Movement - (24.22 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0024 - Movement - (11.4 SQM)	Not Applicable	Circulation or storage space.
OS 502 13510 - OS 502 13510 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 601 19833 - OS 601 19833 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (80)	
OS 602 11500 - OS 602 11500 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (80)	
OS 602 19343 - OS 602 19343 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (80)	
OS 602 19518 - OS 602 19518 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (80)	
OS 606 10956 - OS 606 10956 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (80)	
OS 606 11712 - OS 606 11712 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (80)	
OS 606 16325 - OS 606 16325 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (80)	
OS 606 70041 - OS 606 70041 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (80)	
OS 710 15024 - OS 710 15024 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	