



<b>SCHOOL:</b>	<b>Moonbi Public School (2608)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Tamworth</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tamworth</b>

2608 - Moonbi Public School  
Site Plan (11446)



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Principal - (7.17 SQM)	Office (1)	
B00A - R0007 - Clerical Office/Workroom - (14.88 SQM)	Office (3)	
B00A - R0008 - Practical Activities - 1hb - (22.18 SQM)	Student Space (10)	
B00A - R0009 - Home Base - (51.75 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0010 - Home Base - (75.25 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0012 - Practical Activities - 1hb - (17.17 SQM)	Student Space (7)	
B00A - R0013 - Entry Vestibule - (10.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (15.05 SQM)	Office (3)	
B00B - R0002 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room - (37.9 SQM)	Office (9)	
B00C - R0002 - Canteen - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (71.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Reading Area - (77.99 SQM)	Student Space (36)	
B00F - R0001 - Communal Space - (59.96 SQM)	Student Space (27)	
OS 603 13981 - OS 603 13981 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	