

SCHOOL:	Moorebank High School (8501)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Holsworthy
LOCAL GOVERNMENT AREA:	Liverpool

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (51.99 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R0006 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (52)	
B00A - R0007 - General Learning Space - (51.99 SQM) - Teaching Space: 1	Student Space (56)	
B00A - R0008 - General Learning Space - (51.21 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R0011 - Laboratory L.S. - (90.27 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R0012 - Preparation - Science - (48.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Laboratory L.S. - (88.02 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R0018 - Movement - (22.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (151.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (51.49 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R1004 - Staff Study - (28.87 SQM)	Office (7)	
B00A - R1005 - Computer Learning Space - (52.35 SQM) - Teaching Space: 1	Student Space (52)	
B00A - R1007 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (52)	
B00A - R1008 - General Learning Space - (51.28 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R1010 - Laboratory L.S. - (90.18 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R1013 - Preparation - Science - (48.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Laboratory L.S. - (88.34 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R1016 - Breakout Area - (27.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (16.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Movement - (104.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Movement - (18.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R2004 - Laboratory L.S. - (90.27 SQM) - Teaching Space: 1	Student Space (89)	
B00A - R2007 - Staff Study - (48.72 SQM)	Office (12)	
B00A - R2009 - Laboratory L.S. - (88.34 SQM) - Teaching Space: 1	Student Space (70)	
B00A - R2011 - Movement - (18.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Food Technology L.S. - (65.2 SQM) - Teaching Space: 1	Student Space (70)	
B00B - R0004 - Art Learning Space - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0007 - Art Learning Space - (60.39 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0009 - Wood Technology L.S. - (82.34 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0012 - Wood Technology L.S. - (81.94 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0027 - Design L.S. - (51.85 SQM) - Teaching Space: 1	Student Space (61)	
B00B - R0031 - Metal Technology L.S. - (74.12 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0036 - Metal Technology L.S. - (59.75 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0037 - Welding Area - (14.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Wood Technology Bay - (33.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Design/Technology L.S. - (74.28 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0042 - Staff Study - (12.72 SQM)	Office (3)	
B00B - R0043 - Multi Media Workshop - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Metal Technology Bay - (20.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0054 - Metal Technology Bay - (15.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0056 - Dark Room - (14.63 SQM)	Office (3)	
B00B - R0057 - Staff Study - (29.55 SQM)	Office (7)	
B00B - R1001 - Music Learning Space - (67.5 SQM) - Teaching Space: 1	Student Space (52)	
B00B - R1004 - Music Learning Space - (62.55 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R1012 - Food Technology L.S. - (91.42 SQM) - Teaching Space: 1	Student Space (61)	
B00B - R1015 - Computer Learning Space - (74.39 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1019 - Textiles Technology L.S. - (72.35 SQM) - Teaching Space: 1	Student Space (61)	
B00B - R1023 - Food/Research Space - (39.7 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1024 - Preparation - Materials - (17.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1025 - Food Technology L.S. - (78.86 SQM) - Teaching Space: 1	● Student Space (80)	
B00B - R1027 - Practice/Seminar - (12.39 SQM)	● Student Space (5)	
B00B - R1028 - Practice/Seminar - (18.28 SQM)	● Student Space (8)	
B00B - R1040 - Tea Room - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1041 - Staff Study - (21.58 SQM)	● Office (5)	
B00C - R0005 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (12.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - General Assistants - (10.62 SQM)	● Office (2)	
B00C - R0021 - Stage - (98.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Student Canteen - (52.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Multi-Purpose Space - (458.41 SQM)	● Student Space (181)	
B00C - R0039 - Staff Study - (39.35 SQM)	● Office (9)	
B00D - R0002 - Administration - Executive - (22.64 SQM)	● Office (5)	
B00D - R0008 - Clinic - (10.24 SQM)	● Office (2)	
B00D - R0010 - Principal Office - (22.29 SQM)	● Office (5)	
B00D - R0014 - Interview/Meeting - (10 SQM)	● Office (2)	
B00D - R0016 - Public Reception - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (42.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Administration - Clerical - (26.86 SQM)	● Office (6)	
B00D - R1012 - Movement - (20.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Leading Teacher - (18.25 SQM)	● Office (4)	
B00D - R1017 - Commonroom - (103.62 SQM)	● Office (25)	
B00D - R1018 - Staff Kitchen - (9.65 SQM)	● Office (2)	
B00D - R1019 - Deputy Principal Office - (16.68 SQM)	● Office (4)	
B00E - M0001 - Main Area - (183.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Deputy Principal Office - (16.45 SQM)	● Office (4)	
B00E - R0002 - Administration - Clerical - (15.96 SQM)	● Office (3)	
B00E - R0006 - Audio Visual Workroom - (30.1 SQM)	● Student Space (33)	
B00E - R0012 - Seminar - (15.95 SQM)	● Office (3)	
B00E - R0013 - Seminar - (16.45 SQM)	● Office (4)	
B00E - R0014 - Main Entry - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Main Area - (172.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Tiered Learning Area - (11.63 SQM)	● Student Space (33)	
B00E - R0022 - Tiered Learning Area - (8.3 SQM)	● Student Space (3)	
B00E - R0023 - Movement - (46.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Senior Study - (62.34 SQM)	● Office (15)	
B00E - R1002 - Movement Studio - (88.05 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - General Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (89)	
B00F - R0002 - General Learning Space - (56.62 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R0003 - General Learning Space - (50.27 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R0005 - General Learning Space - (51.56 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R0006 - General Learning Space - (51.14 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R0011 - General Learning Space - (50.55 SQM) - Teaching Space: 1	● Student Space (56)	
B00F - R0012 - General Learning Space - (50.67 SQM) - Teaching Space: 1	● Student Space (56)	
B00F - R0013 - General Learning Space - (51.35 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R0018 - Interview/Office - Type 1 - (12.53 SQM)	● Office (3)	
B00F - R0022 - Staff Study - (21.26 SQM)	● Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0030 - General Learning Space - (49.43 SQM) - Teaching Space: 1	● Student Space (38)	
B00F - R0031 - Movement - (151.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0033 - Staff Study - (28.24 SQM)	● Office (7)	
B00F - R1001 - General Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (89)	
B00F - R1002 - General Learning Space - (56.73 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R1003 - General Learning Space - (51.14 SQM) - Teaching Space: 1	● Student Space (56)	
B00F - R1005 - General Learning Space - (50.71 SQM) - Teaching Space: 1	● Student Space (56)	
B00F - R1006 - General Learning Space - (51.57 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R1010 - Staff Study - (38.86 SQM)	● Office (9)	
B00F - R1011 - General Learning Space - (51 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1012 - General Learning Space - (51.07 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1013 - General Learning Space - (51.64 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1016 - Leading Teacher - (12.53 SQM)	● Office (3)	
B00F - R1021 - Movement - (153.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R1022 - Staff Study - (21.18 SQM)	● Office (5)	
B00F - R1026 - Staff Study - (26.94 SQM)	● Office (6)	
B00F - R2001 - General Learning Space - (41.82 SQM) - Teaching Space: 1	● Student Space (47)	
B00F - R2002 - General Learning Space - (57.68 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R2003 - General Learning Space - (51.21 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R2005 - General Learning Space - (51.21 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R2006 - General Learning Space - (50.84 SQM) - Teaching Space: 1	● Student Space (61)	
B00F - R2011 - General Learning Space - (49.55 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R2012 - Interview/Office - Type 1 - (15.87 SQM)	● Office (3)	
B00F - R2016 - Deputy Principal Office - (21.73 SQM)	● Office (5)	
B00F - R2017 - Computer Learning Space - (63.63 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R2018 - Movement - (119.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R2023 - Staff Study - (28.37 SQM)	● Office (7)	
OS 523 10642 - OS 523 10642 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 600 17439 - OS 600 17439 - Learning Unit - Small - (57 SQM)	● Student Space (52)	
OS 600 18145 - OS 600 18145 - Learning Unit - Small - (57 SQM)	● Student Space (52)	
OS 600 18148 - OS 600 18148 - Learning Unit - Small - (57 SQM)	● Student Space (52)	