

SCHOOL:	Northern Beaches Secondary College Cromer Campus (8511)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Wakehurst
LOCAL GOVERNMENT AREA:	Northern Beaches

8511 - Northern Beaches Secondary College Cromer Campus
Site Plan (10944)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0002 - Main Entry - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Main Area - (192.96 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Audio Visual Workroom - (46.55 SQM)	● Student Space (21)	
B00L - R0011 - Movement - (29.26 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Tiered Learning Area - (12.63 SQM)	● Student Space (5)	
B00L - R1003 - Main Area - (120.94 SQM)	Not Applicable	Circulation or storage space.
B00L - R1004 - Seminar - Type 1 - (15.37 SQM)	● Office (3)	
B00L - R1005 - Staff Study - (15.57 SQM)	● Office (3)	
B00L - R1008 - Staff Study - (15.1 SQM)	● Office (3)	
B00L - R1016 - Seminar - (31.22 SQM)	● Office (7)	
B00L - R1019 - Computer Learning Space - (96.69 SQM) - Teaching Space: 1	● Student Space (39)	
BOAM - R0011 - Administration - Clerical - (13.51 SQM)	● Office (3)	
BOAM - R0012 - Interview/Office - Type 1 - (13.43 SQM)	● Office (3)	
BOAM - R0016 - Fitness Laboratory - (55.79 SQM)	● Student Space (25)	
BOAM - R0022 - Movement - (11.78 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0029 - Principal Office - (24.16 SQM)	● Office (6)	
BOAM - R0031 - Public Reception - (16.93 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0032 - Movement - (47.54 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0035 - Movement - (18.75 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0041 - Administration - Clerical - (28.83 SQM)	● Office (7)	
BOAM - R0042 - Administration - Clerical - (12.12 SQM)	● Office (3)	
BOAM - R0049 - Commonroom - (114.81 SQM)	● Office (28)	
BOAM - R0050 - Staff Kitchen - (10.75 SQM)	● Office (2)	
BOAM - R0051 - Senior Study - (80.43 SQM)	● Office (20)	
BOAM - R0052 - Senior Study - (11.65 SQM)	● Office (2)	
BOAM - R0064 - Administration - Clerical - (38.45 SQM)	● Office (9)	
BOAM - R0065 - Interview/Meeting - (7.58 SQM)	● Office (1)	
BOAM - R1002 - Ancillary Staff - (16.61 SQM)	● Office (4)	
BOAM - R1005 - Clinic - (12.68 SQM)	● Office (3)	
BOAM - R1010 - Staff Study - (39.44 SQM)	● Office (9)	
BOAM - R1011 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1012 - General Learning Space - (64.89 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1013 - General Learning Space - (64.57 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1014 - General Learning Space - (53.46 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1016 - Computer Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1017 - Computer Learning Space - (52.02 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1018 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (33)	
BOAM - R1020 - Staff Study - (35.88 SQM)	● Office (8)	
BOAM - R1022 - Movement - (74.37 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1024 - Movement - (20.76 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1028 - Staff Study - (27.82 SQM)	● Office (6)	
BOC1 - R0001 - Art Learning Space - (61.81 SQM) - Teaching Space: 1	● Student Space (34)	
BOC1 - R0002 - Art Learning Space - (94.25 SQM) - Teaching Space: 1	● Student Space (52)	
BOC1 - R1005 - Staff Study - (19.76 SQM)	● Office (4)	
BOC1 - R1006 - Staff Study - (13.54 SQM)	● Office (3)	
BOC1 - R1011 - Design L.S. - (68.81 SQM) - Teaching Space: 1	● Student Space (37)	
BOC1 - R1014 - Design L.S. - (68.96 SQM) - Teaching Space: 1	● Student Space (37)	
BOC2 - R0001 - Art Learning Space - (65.61 SQM) - Teaching Space: 1	● Student Space (36)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC2 - R0004 - Wood Technology L.S. - (78.64 SQM) - Teaching Space: 1	● Student Space (43)	
BOC2 - R0005 - Wood Technology Bay - (25.97 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0006 - Wood Technology Bay - (6.45 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0007 - Wood Technology L.S. - (78.46 SQM) - Teaching Space: 1	● Student Space (43)	
BOC2 - R1004 - Food Technology L.S. - (95.44 SQM) - Teaching Space: 1	● Student Space (53)	
BOC2 - R1008 - Food Technology L.S. - (94.17 SQM) - Teaching Space: 1	● Student Space (52)	
BOC2 - R1014 - Preparation - Materials - (31.79 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0001 - Design L.S. - (65.31 SQM) - Teaching Space: 1	● Student Space (36)	
BOC3 - R0003 - Metal Technology L.S. - (65.85 SQM) - Teaching Space: 1	● Student Space (36)	
BOC3 - R0006 - Metal Technology Bay - (24.95 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0007 - Metal Technology Bay - (8.79 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0023 - Metal Technology L.S. - (68.41 SQM) - Teaching Space: 1	● Student Space (37)	
BOC3 - R0024 - Welding Area - (10.1 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0026 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1001 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1014 - Staff Study - (52.3 SQM)	○ Office (13)	
BOC3 - R1016 - Design/Technology L.S. - (65.78 SQM) - Teaching Space: 1	● Student Space (36)	
BOC3 - R1020 - Design/Technology L.S. - (65.22 SQM) - Teaching Space: 1	● Student Space (36)	
BOC3 - R1023 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
BOEL - R0001 - General Learning Space - (53.17 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0002 - General Learning Space - (52.03 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0003 - General Learning Space - (65.98 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0004 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0010 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0011 - General Learning Space - (54.19 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0015 - General Learning Space - (53.97 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R0022 - Staff Study - (43.97 SQM)	○ Office (10)	
BOEL - R0024 - Staff Study - (23.05 SQM)	○ Office (5)	
BOEL - R1001 - Special Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1002 - General Learning Space - (51 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1003 - General Learning Space - (65.77 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1004 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1005 - Staff Study - (47.09 SQM)	○ Office (11)	
BOEL - R1010 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1011 - General Learning Space - (53.17 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1012 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1013 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (33)	
BOEL - R1016 - Staff Study - (23.01 SQM)	○ Office (5)	
BOHC - R0001 - General Learning Space - (66.99 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R0002 - General Learning Space - (66.64 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R0003 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R0008 - Computer Learning Space - (52.73 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R0009 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R0017 - Staff Study - (41.35 SQM)	○ Office (10)	
BOHC - R0018 - Staff Study - (23.97 SQM)	○ Office (5)	
BOHC - R1001 - Special Learning Space - (65.99 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R1002 - Special Learning Space - (64.75 SQM) - Teaching Space: 1	● Student Space (33)	
BOHC - R1003 - Special Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (33)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0HC - R1009 - General Learning Space - (72.99 SQM) - Teaching Space: 1	● Student Space (33)	
B0HC - R1010 - Special Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (33)	
B0HC - R1016 - Tea Room - (5.23 SQM)	Not Applicable	Circulation or storage space.
B0HC - R1017 - Staff Study - (20.24 SQM)	● Office (5)	
B0HC - R1019 - Staff Study - (22.61 SQM)	● Office (5)	
B0S1 - R0006 - Staff Study - (38.37 SQM)	● Office (9)	
B0S1 - R0009 - Staff Study - (24.64 SQM)	● Office (6)	
B0S2 - R0001 - Laboratory L.S. - (93.89 SQM) - Teaching Space: 1	● Student Space (37)	
B0S2 - R0003 - Preparation - Science - (34.26 SQM)	Not Applicable	Circulation or storage space.
B0S2 - R0005 - Laboratory L.S. - (94.09 SQM) - Teaching Space: 1	● Student Space (37)	
B0S2 - R1001 - Laboratory L.S. - (92.77 SQM) - Teaching Space: 1	● Student Space (37)	
B0S2 - R1005 - General Learning Space - (92.78 SQM) - Teaching Space: 1	● Student Space (37)	
B0S3 - R0001 - Laboratory L.S. - (93.9 SQM) - Teaching Space: 1	● Student Space (37)	
B0S3 - R0002 - Preparation - Science - (54.69 SQM)	Not Applicable	Circulation or storage space.
B0S3 - R0005 - Laboratory L.S. - (93.71 SQM) - Teaching Space: 1	● Student Space (37)	
B0S3 - R1001 - Laboratory L.S. - (92.69 SQM) - Teaching Space: 1	● Student Space (37)	
B0S3 - R1002 - Preparation - Science - (53.89 SQM)	Not Applicable	Circulation or storage space.
B0S3 - R1006 - Laboratory L.S. - (93.07 SQM) - Teaching Space: 1	● Student Space (37)	
B0SC - R0001 - Performance Workspace - (99.82 SQM) - Teaching Space: 1	● Student Space (55)	
B0SC - R0006 - Multi-Purpose Space - (457.12 SQM)	● Student Space (212)	
B0SC - R0012 - General Assistants - (11.4 SQM)	● Office (2)	
B0SC - R0032 - Student Canteen - (92.53 SQM)	Not Applicable	Circulation or storage space.
B0SC - R1001 - Movement - (25.31 SQM)	Not Applicable	Circulation or storage space.
B0SC - R1013 - Music Learning Space - (82.57 SQM) - Teaching Space: 1	● Student Space (46)	
B0SC - R1016 - Music Learning Space - (79.18 SQM) - Teaching Space: 1	● Student Space (43)	
B0SC - R1026 - General Learning Space - (45.77 SQM) - Teaching Space: 1	● Student Space (25)	
B0SC - R1029 - Photographic Studio - (28.51 SQM)	● Office (7)	
B0SC - R1035 - Independent Learning Space - (42.58 SQM) - Teaching Space: 1	● Student Space (23)	