


SCHOOL:	Taren Point Public School (3168)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland

3168 - Taren Point Public School
Site Plan (12051)


















1:843

Printed: 17-Apr-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Home Base - (46.92 SQM) - Teaching Space: 1	 Student Space (46)	
B00A - R0007 - Home Base - (64.62 SQM) - Teaching Space: 1	 Student Space (73)	
B00A - R0009 - Principal - (17.56 SQM)	 Office (4)	
B00A - R0010 - Sick Bay - (6.2 SQM)	 Student Space (2)	
B00A - R0014 - Movement - (53.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Clerical Office - (13.28 SQM)	 Office (3)	
B00A - R0020 - Computer Room - (47.11 SQM)	 Student Space (21)	
B00B - R0002 - Home Base - (46.79 SQM) - Teaching Space: 1	 Student Space (42)	
B00B - R0003 - Home Base - (46.79 SQM) - Teaching Space: 1	 Student Space (42)	
B00B - R0004 - Canteen - (14.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Home Base - (80.69 SQM) - Teaching Space: 1	 Student Space (445)	
B00C - R0021 - Movement - (8.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Principal - (14.02 SQM)	 Office (3)	
B00C - R0023 - Seminar/Study - (7.79 SQM)	 Office (1)	
B00C - R0024 - Movement - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Clerical/Printing - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Staff Room - (14.55 SQM)	 Office (3)	
B00C - R0029 - Entry Vestibule - (8.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Clerical Office - (40.48 SQM)	 Office (10)	
B00E - R0001 - Communal Space - (62.95 SQM)	 Student Space (29)	
B00F - R0001 - Reading Area - (91.42 SQM)	 Student Space (42)	