

SCHOOL:	The Rivers Secondary College Kadina High Campus (8520)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Lismore

8520 - The Rivers Secondary College Kadina High Campus
Site Plan (12557)









Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Duplicating Workroom - (24.84 SQM)	Office (6)	
B00A - R0004 - Administration - Clerical - (25.52 SQM)	Office (6)	
B00A - R0005 - Principal Office - (27.07 SQM)	Office (6)	
B00A - R0006 - Administration - Clerical - (16.11 SQM)	Office (4)	
B00A - R0007 - Deputy Principal Office - (25.18 SQM)	Office (6)	
B00A - R0008 - Clinic - Boys - (15.27 SQM)	Office (3)	
B00A - R0011 - Clinic - Girls - (15.15 SQM)	Office (3)	
B00A - R0012 - Administration - Clerical - (12.85 SQM)	Office (3)	
B00A - R0013 - Administration - Clerical - (12.85 SQM)	Office (3)	
B00A - R0014 - Interview/Office - Type 1 - (13.07 SQM)	Office (3)	
B00A - R0017 - Movement - (90.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Commonroom - (114.81 SQM)	Office (28)	
B00A - R0022 - Staff Study - (7.67 SQM)	Office (1)	
B00A - R0023 - Laboratory L.S. - (93.58 SQM) - Teaching Space: 1	Student Space (186)	
B00A - R0024 - Preparation - (49.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Laboratory L.S. - (93.58 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R0026 - Growing/Breeding - (31.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Laboratory L.S. - (92.66 SQM) - Teaching Space: 1	Student Space (186)	
B00A - R0030 - Darkroom Space - (49.63 SQM)	Office (12)	
B00A - R0031 - Laboratory L.S. - (92.66 SQM) - Teaching Space: 1	Student Space (186)	
B00A - R0032 - General Assistants - (31.56 SQM)	Office (7)	
B00A - R0034 - General Learning Space - (88.67 SQM) - Teaching Space: 1	Student Space (297)	
B00A - R0038 - Movement - (149.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (135.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Laboratory L.S. - (93.58 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1004 - Laboratory L.S. - (92.86 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1005 - Staff Study - (31.06 SQM)	Office (7)	
B00A - R1006 - General Learning Space - (61.82 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1008 - General Learning Space - (57 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1009 - General Learning Space - (56.82 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1010 - General Learning Space - (56.82 SQM) - Teaching Space: 1	Student Space (186)	
B00A - R1011 - Staff Study - (32.89 SQM)	Office (8)	
B00A - R1016 - Movement - (144.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1018 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1019 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1020 - General Learning Space - (52.4 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1021 - Staff Study - (40.6 SQM)	Office (10)	
B00A - R1025 - Computer Learning Space - (51.75 SQM) - Teaching Space: 1	Student Space (297)	
B00A - R1026 - Computer Learning Space - (50.83 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1027 - Movement - (192.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - General Learning Space - (49.24 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1030 - General Learning Space - (49.17 SQM) - Teaching Space: 1	Student Space (223)	
B00A - R1031 - Staff Study - (33.83 SQM)	Office (8)	
B00A - R1035 - Preparation - (39.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Staff Study - (52.13 SQM)	Office (13)	
B00B - R0006 - General Learning Space - (51.4 SQM) - Teaching Space: 1	Student Space (223)	
B00B - R0007 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (223)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0008 - General Learning Space - (51.41 SQM) - Teaching Space: 1	● Student Space (223)	
B00B - R0009 - General Learning Space - (50.45 SQM) - Teaching Space: 1	● Student Space (223)	
B00B - R0015 - Movement - (103.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Staff Study - (50.27 SQM)	● Office (12)	
B00B - R1006 - General Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (223)	
B00B - R1007 - General Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (223)	
B00B - R1008 - General Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (223)	
B00B - R1009 - Movement - (115.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - General Learning Space - (51.77 SQM) - Teaching Space: 1	● Student Space (223)	
B00B - R1011 - Performance Workspace - (51.69 SQM) - Teaching Space: 1	● Student Space (223)	
B00C - R0001 - Staff Study - (35.07 SQM)	● Office (8)	
B00C - R0009 - Art Learning Space - (52.4 SQM) - Teaching Space: 1	● Student Space (186)	
B00C - R0010 - Art Learning Space - (53.21 SQM) - Teaching Space: 1	● Student Space (186)	
B00C - R0011 - Workshop - (53.45 SQM)	● Student Space (24)	
B00C - R0013 - Art Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (186)	
B00C - R0016 - Materials Technology L.S. - (104.31 SQM) - Teaching Space: 1	● Student Space (297)	
B00C - R0018 - Materials Technology L.S. - (82.65 SQM) - Teaching Space: 1	● Student Space (186)	
B00C - R0019 - Wood Technology Bay - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (196.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0032 - Movement - (9.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Metal Technology Bay - (196.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0038 - Hospitality Space - (31.25 SQM)	● Student Space (14)	
B00C - R0039 - Kitchen - Type 2 - (108.64 SQM)	● Student Space (50)	
B00C - R0040 - Preparation - Materials - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0041 - Entry - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0044 - Movement - (15.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0045 - Welding Area - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0046 - Welding Area - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0047 - Entry - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Darkroom Space - (17.73 SQM)	● Office (4)	
B00C - R1002 - Materials Technology L.S. - (66.52 SQM) - Teaching Space: 1	● Student Space (297)	
B00C - R1005 - Materials Technology L.S. - (66.52 SQM) - Teaching Space: 1	● Student Space (297)	
B00C - R1008 - Staff Study - (35.89 SQM)	● Office (8)	
B00C - R1009 - Computer Learning Space - (53.28 SQM) - Teaching Space: 1	● Student Space (223)	
B00C - R1011 - Design L.S. - (53.28 SQM) - Teaching Space: 1	● Student Space (223)	
B00C - R1013 - Movement - (164.96 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Entry - (25.67 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Workroom - (22.69 SQM)	● Office (5)	
B00L - R0006 - Audio Visual Workroom - (24.79 SQM)	● Student Space (11)	
B00L - R0009 - Seminar - (9.1 SQM)	● Office (2)	
B00L - R0010 - Seminar - (12.23 SQM)	● Office (3)	
B00L - R0011 - Seminar - (12.29 SQM)	● Office (3)	
B00L - R0012 - Seminar - (9.1 SQM)	● Office (2)	
B00L - R0014 - Main Area - (140.3 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Main Area - (96.03 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Main Area - (74.87 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Study Space - (169.75 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Multi-Purpose Space - (455.59 SQM)	● Student Space (211)	
B00S - R0012 - Student Canteen - (64.87 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R0014 - Staff Study - (11.39 SQM)	 Office (2)	
B00S - R0015 - Staff Study - (11.47 SQM)	 Office (2)	
B00S - R0027 - Movement - (165.78 SQM)	Not Applicable	Circulation or storage space.
B00S - R0029 - Movement - (23.51 SQM)	Not Applicable	Circulation or storage space.
B00S - R0033 - Movement - (211.59 SQM)	Not Applicable	Circulation or storage space.
B00S - R1003 - Music Learning Space - (70.3 SQM) - Teaching Space: 1	 Student Space (223)	
B00S - R1004 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00S - R1006 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00S - R1008 - Food Technology L.S. - (99.54 SQM) - Teaching Space: 1	 Student Space (297)	
B00S - R1010 - Preparation - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00S - R1012 - Food/Research Space - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00S - R1013 - Food Technology L.S. - (101.76 SQM) - Teaching Space: 1	 Student Space (75)	
B00S - R1018 - Movement - (141.84 SQM)	Not Applicable	Circulation or storage space.
B00S - R1023 - Movement - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00S - R1024 - Performance Workshop - (118.21 SQM)	 Student Space (54)	
B00S - R1025 - Movement - (78.87 SQM)	Not Applicable	Circulation or storage space.