

SCHOOL:	Tomaree High School (8502)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Port Stephens
LOCAL GOVERNMENT AREA:	Port Stephens

8502 - Tomaree High School
Site Plan (13581)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOA2 - R0001 - Movement - (43.37 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0004 - Senior Seminar - (11.64 SQM)	Office (2)	
BOD1 - R0005 - Senior Seminar - (11.67 SQM)	Office (2)	
BOD1 - R0006 - Senior Study - (48.03 SQM)	Office (12)	
BOD1 - R0007 - Audio Visual Workroom - (35.33 SQM)	Student Space (16)	
BOD1 - R0010 - Entry - (28.81 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0011 - Seminar - (10.81 SQM)	Office (2)	
BOD1 - R0012 - Main Area - (559.38 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0013 - Computer Learning Space - (53.72 SQM) - Teaching Space: 1	Student Space (53)	
BOD1 - R0016 - Movement - (16.61 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0022 - Main Area - (134.84 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R1002 - Design/Technology L.S. - (72.27 SQM) - Teaching Space: 1	Student Space (70)	
BOD1 - R1006 - Computer Learning Space - (59.41 SQM) - Teaching Space: 1	Student Space (53)	
BOD1 - R1007 - Design/Technology L.S. - (72.42 SQM) - Teaching Space: 1	Student Space (70)	
BOD1 - R1012 - Movement - (177.22 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R1013 - Interview/Office - Type 1 - (22.2 SQM)	Office (5)	
BOE1 - R0001 - Staff Lounge - (116.37 SQM)	Office (29)	
BOE1 - R0004 - Staff Study - (87.13 SQM)	Office (21)	
BOE1 - R0007 - Interview - (10.46 SQM)	Office (2)	
BOE1 - R0008 - Interview - (17.34 SQM)	Office (4)	
BOE1 - R0009 - Interview - (10.48 SQM)	Office (2)	
BOE1 - R0010 - Interview - (12.68 SQM)	Office (3)	
BOE1 - R0020 - Movement - (39.86 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0026 - Staff Kitchen - (15.72 SQM)	Office (3)	
BOE1 - R0027 - Movement - (27.02 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1001 - Staff Study - (116.64 SQM)	Office (29)	
BOE1 - R1002 - Staff Study - (175.52 SQM)	Office (43)	
BOE1 - R1003 - Interview - (13.05 SQM)	Office (3)	
BOE1 - R1004 - Interview - (13.01 SQM)	Office (3)	
BOE1 - R1010 - Duplicating Workroom - (15.85 SQM)	Office (3)	
BOE1 - R1012 - Movement - (38.29 SQM)	Not Applicable	Circulation or storage space.
BOF1 - R0003 - Seminar - (13.55 SQM)	Office (3)	
BOF1 - R0010 - General Learning Space - (49.21 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R0011 - General Learning Space - (60.9 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R0012 - General Learning Space - (59.48 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R0013 - General Learning Space - (60.15 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R1001 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
BOF1 - R1004 - Seminar - (12.69 SQM)	Office (3)	
BOF1 - R1010 - General Learning Space - (47.96 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R1011 - General Learning Space - (59.43 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R1012 - General Learning Space - (59.33 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R1013 - General Learning Space - (59.5 SQM) - Teaching Space: 1	Student Space (112)	
BOF1 - R1014 - General Learning Space - (59.41 SQM) - Teaching Space: 1	Student Space (112)	
BOG1 - R0001 - Clinic - Boys - (14.24 SQM)	Office (3)	
BOG1 - R0004 - Duplicating Workroom - (54.2 SQM)	Office (13)	
BOG1 - R0005 - Interview - (14.08 SQM)	Office (3)	
BOG1 - R0006 - Interview - (12.15 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0G1 - R0007 - Principal - (17.31 SQM)	Office (4)	
B0G1 - R0009 - Leading Teacher - (11.98 SQM)	Office (2)	
B0G1 - R0011 - Public Entry - (23.92 SQM)	Not Applicable	Circulation or storage space.
B0G1 - R0012 - Clerical Office - (78.59 SQM)	Office (19)	
B0G1 - R0013 - Movement - (52.4 SQM)	Not Applicable	Circulation or storage space.
B0G1 - R0015 - Leading Teacher - (13.01 SQM)	Office (3)	
B0G1 - R0016 - Clinic - Girls - (14.23 SQM)	Office (3)	
B0G1 - R0027 - Movement - (41.74 SQM)	Not Applicable	Circulation or storage space.
B0H1 - R0013 - General Learning Space - (47.97 SQM) - Teaching Space: 1	Student Space (51)	
B0H1 - R0022 - Movement - (95.04 SQM)	Not Applicable	Circulation or storage space.
B0H1 - R1005 - Seminar - (15.22 SQM)	Office (3)	
B0H1 - R1008 - General Learning Space - (48.04 SQM) - Teaching Space: 1	Student Space (53)	
B0H1 - R1009 - General Learning Space - (47.89 SQM) - Teaching Space: 1	Student Space (53)	
B0H1 - R1010 - General Learning Space - (47.89 SQM) - Teaching Space: 1	Student Space (53)	
B0H1 - R1011 - General Learning Space - (47.88 SQM) - Teaching Space: 1	Student Space (53)	
B0H1 - R1012 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (53)	
B0H1 - R1013 - General Learning Space - (47.67 SQM) - Teaching Space: 1	Student Space (53)	
B0J1 - R0001 - General Learning Space - (59.73 SQM) - Teaching Space: 1	Student Space (85)	
B0J1 - R0002 - General Learning Space - (60.04 SQM) - Teaching Space: 1	Student Space (68)	
B0J1 - R0003 - General Learning Space - (59.83 SQM) - Teaching Space: 1	Student Space (85)	
B0J1 - R1001 - General Learning Space - (59.64 SQM) - Teaching Space: 1	Student Space (85)	
B0J1 - R1002 - General Learning Space - (60.04 SQM) - Teaching Space: 1	Student Space (68)	
B0J1 - R1003 - General Learning Space - (60.12 SQM) - Teaching Space: 1	Student Space (85)	
B0K1 - R0001 - General Learning Space - (60.05 SQM) - Teaching Space: 1	Student Space (85)	
B0K1 - R0002 - General Learning Space - (59.7 SQM) - Teaching Space: 1	Student Space (85)	
B0K1 - R0003 - General Learning Space - (61.51 SQM) - Teaching Space: 1	Student Space (85)	
B0K1 - R0004 - Interview - (16.07 SQM)	Office (4)	
B0K1 - R1001 - General Learning Space - (59.89 SQM) - Teaching Space: 1	Student Space (85)	
B0K1 - R1002 - General Learning Space - (60.43 SQM) - Teaching Space: 1	Student Space (85)	
B0K1 - R1003 - General Learning Space - (61.55 SQM) - Teaching Space: 1	Student Space (100)	
B0K1 - R1004 - Interview - (15.63 SQM)	Office (3)	
B0L1 - R0002 - Canteen - (57.26 SQM)	Not Applicable	Circulation or storage space.
B0M1 - M0001 - Multi-Purpose Space - (134.54 SQM)	Student Space (62)	
B0M1 - R0001 - Movement - (31.73 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0004 - Movement - (31.73 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0005 - Ancillary Staff - (10.72 SQM)	Office (2)	
B0M1 - R0006 - Staff Kitchen - (18.54 SQM)	Office (4)	
B0M1 - R0007 - Public Entry - (55.3 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0012 - Movement - (12.13 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0019 - Movement - (19.82 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0021 - Movement - (29.71 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0022 - Performance Workshop - (34.98 SQM)	Student Space (16)	
B0M1 - R0023 - Movement - (13.15 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0024 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0029 - Stage - (128.61 SQM)	Not Applicable	Circulation or storage space.
B0M1 - R0034 - Multi-Purpose Space - (612.69 SQM)	Student Space (284)	
B0N1 - R0001 - Laboratory L.S. - (91.42 SQM) - Teaching Space: 1	Student Space (63)	
B0N1 - R0002 - Laboratory L.S. - (91.21 SQM) - Teaching Space: 1	Student Space (63)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0N1 - R0003 - Laboratory L.S. - (91.11 SQM) - Teaching Space: 1	● Student Space (63)	
B0N1 - R0004 - Laboratory L.S. - (91.11 SQM) - Teaching Space: 1	● Student Space (63)	
B0N1 - R0005 - Interview - (12.52 SQM)	● Office (3)	
B0N1 - R0007 - Laboratory L.S. - (90.99 SQM) - Teaching Space: 1	● Student Space (52)	
B0N1 - R0011 - Growing/Breeding - (6.18 SQM)	Not Applicable	Circulation or storage space.
B0N1 - R0012 - Preparation - (62.57 SQM)	Not Applicable	Circulation or storage space.
B0N1 - R0015 - Laboratory L.S. - (91.3 SQM) - Teaching Space: 1	● Student Space (55)	
B0N1 - R0017 - Movement - (17.02 SQM)	Not Applicable	Circulation or storage space.
B0N1 - R0018 - Movement - (36.38 SQM)	Not Applicable	Circulation or storage space.
B0P1 - R0001 - General Assistants - (29.01 SQM)	● Office (7)	
B0P1 - R0008 - General Learning Space - (60.55 SQM) - Teaching Space: 1	● Student Space (111)	
B0Q1 - R0001 - Music Learning Space - (73.78 SQM) - Teaching Space: 1	● Student Space (77)	
B0Q1 - R0002 - Practice/Seminar - (10.17 SQM)	Not Applicable	Circulation or storage space.
B0Q1 - R0004 - Practice/Seminar - (14.69 SQM)	Not Applicable	Circulation or storage space.
B0Q1 - R0005 - Music Learning Space - (74.58 SQM) - Teaching Space: 1	● Student Space (72)	
B0Q1 - R0007 - Darkroom Space - (30.74 SQM)	● Office (7)	
B0Q1 - R0008 - Performance Workspace - (91.65 SQM) - Teaching Space: 1	● Student Space (72)	
B0R1 - R0001 - Art Learning Space - (76.19 SQM) - Teaching Space: 1	● Student Space (67)	
B0R1 - R0002 - Art Learning Space - (76.19 SQM) - Teaching Space: 1	● Student Space (67)	
B0R1 - R0003 - Workshop - (76.27 SQM)	● Student Space (35)	
B0R1 - R0004 - Art Learning Space - (76.36 SQM) - Teaching Space: 1	● Student Space (67)	
B0R1 - R0010 - Design L.S. - (76.2 SQM) - Teaching Space: 1	● Student Space (67)	
B0R1 - R0011 - Seminar - (15.33 SQM)	● Office (3)	
B0R1 - R0013 - Design L.S. - (76.63 SQM) - Teaching Space: 1	● Student Space (67)	
B0R1 - R0014 - Design L.S. - (76.26 SQM) - Teaching Space: 1	● Student Space (67)	
B0R1 - R0022 - Food Technology L.S. - (117.53 SQM) - Teaching Space: 1	● Student Space (75)	
B0R1 - R0025 - Food Technology L.S. - (81.52 SQM) - Teaching Space: 1	● Student Space (38)	
B0R1 - R0026 - Food/Research Space - (37.39 SQM)	Not Applicable	Circulation or storage space.
B0R1 - R0027 - Preparation - (16.5 SQM)	Not Applicable	Circulation or storage space.
B0R1 - R0028 - Preparation - (18.94 SQM)	Not Applicable	Circulation or storage space.
B0S1 - R0001 - Materials Technology L.S. - (90.79 SQM) - Teaching Space: 1	● Student Space (51)	
B0S1 - R0004 - Metal Technology Bay - (35.31 SQM)	Not Applicable	Circulation or storage space.
B0S1 - R0007 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B0S1 - R0010 - Workshop Area - (87.03 SQM)	● Student Space (40)	
B0S1 - R0011 - Materials Technology L.S. - (108.39 SQM) - Teaching Space: 1	● Student Space (64)	
B0S1 - R0012 - Wood Technology Bay - (43.69 SQM)	Not Applicable	Circulation or storage space.
B0S1 - R0014 - Materials Technology L.S. - (99.66 SQM) - Teaching Space: 1	● Student Space (64)	
B0S1 - R0016 - Welding Area - (8.92 SQM)	Not Applicable	Circulation or storage space.
B0S1 - R0017 - Welding Area - (8.92 SQM)	Not Applicable	Circulation or storage space.
B0U1 - R0001 - Seminar - (15.38 SQM)	● Office (3)	
B0V1 - R0005 - Movement - (21.24 SQM)	Not Applicable	Circulation or storage space.
B0Z1 - R0003 - Multi-Purpose Space - (40.16 SQM)	● Student Space (18)	
NS 020 13150 - NS 020 13150 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
NS 120 11222 - NS 120 11222 - Learning Unit Primary Single - PWD - (76 SQM)	● Student Space (35)	
OS 521 10539 - OS 521 10539 - Staff Study - (76 SQM)	● Office (19)	
OS 601 10016 - OS 601 10016 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10277 - OS 601 10277 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11437 - OS 601 11437 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15437 - OS 601 15437 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 700 15776 - OS 700 15776 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 710 12193 - OS 710 12193 - Home Science/Pantry/Laundry - (95 SQM)	Office (23)	
OS 720 10792 - OS 720 10792 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 13101 - OS 760 13101 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.