


<b>SCHOOL:</b>	<b>Toomelah Public School (3239)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Northern Tablelands</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Moree Plains</b>

3239 - Toomelah Public School  
Site Plan (10501)



1:769

Printed: 21-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Staff Room Annexe - (16.76 SQM)	Office (4)	
B00A - R0009 - Staff Room - (27.3 SQM)	Office (6)	
B00A - R0010 - Entry Vestibule - (17.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Sick Bay - (7.91 SQM)	Student Space (3)	
B00A - R0013 - Principal - (16.16 SQM)	Office (4)	
B00A - R0014 - Interview - (12 SQM)	Office (3)	
B00A - R0016 - Movement - (18.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Deputy Principal - (12.04 SQM)	Office (3)	
B00A - R0019 - Duplicating Workroom - (20.04 SQM)	Office (5)	
B00A - R0020 - Clerical Office - (12.04 SQM)	Office (3)	
B00A - R0026 - Canteen - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Communal Space - (98.2 SQM)	Student Space (45)	
B00A - R0030 - Raised Platform - (24.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Staff Room Annexe - (5.43 SQM)	Office (1)	
B00A - R0045 - Home Base - (58.57 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0046 - Home Base - (54.68 SQM) - Teaching Space: 1	Student Space (43)	
B00A - R0048 - Practical Activities - 1hb - (34.61 SQM)	Student Space (16)	
B00A - R0051 - Withdrawal Space - 1hb - (12.04 SQM)	Student Space (5)	
B00A - R0054 - Reading Area - (88.37 SQM)	Student Space (40)	
B00A - R0060 - Practical Activities - 1hb - (34.73 SQM)	Student Space (16)	
B00A - R0061 - Staff Room Annexe - (5.18 SQM)	Office (1)	
B00A - R0062 - Home Base - (59.07 SQM) - Teaching Space: 1	Student Space (52)	
B00A - R0065 - Home Base - (58.7 SQM) - Teaching Space: 1	Student Space (52)	
B00A - R0066 - Withdrawal Space - 1hb - (5.95 SQM)	Student Space (2)	
B00A - R0068 - Special Programs Room - (34.39 SQM)	Student Space (15)	
B00A - R0070 - Movement - (475.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (23.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Special Programs Room - (12.77 SQM)	Student Space (5)	
B00E - R0003 - Movement - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Kitchen - (15.18 SQM)	Office (3)	
B00E - R0008 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Practical Activities - 1hb - (47.87 SQM)	Student Space (22)	
B00G - R0002 - Movement - (120.64 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (24.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Practical Activities - 1hb - (28.09 SQM)	Student Space (13)	
B00G - R1005 - Home Base - (67.17 SQM) - Teaching Space: 1	Student Space (37)	
B00G - R1006 - Withdrawal Space - 1hb - (6.15 SQM)	Student Space (2)	
B00H - R0001 - Canteen - (13.63 SQM)	Not Applicable	Circulation or storage space.