

SCHOOL:	Trundle Central School (3259)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Parkes

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (40.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (34.7 SQM)	Office (8)	
B00A - R0004 - Sick Bay - (8.69 SQM)	Student Space (4)	
B00A - R0007 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Room Annexe - (18.48 SQM)	Office (4)	
B00A - R0016 - Deputy Principal - (12.84 SQM)	Office (3)	
B00A - R0018 - Principal - (16.98 SQM)	Office (4)	
B00A - R0019 - Deputy Principal - (12.87 SQM)	Office (3)	
B00A - R0020 - Interview - (12.88 SQM)	Office (3)	
B00A - R0021 - Staff Kitchen - (11.1 SQM)	Office (2)	
B00A - R0022 - Commonroom - (36.04 SQM)	Office (9)	
B00B - R0002 - Home Base - (44.19 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0003 - Home Base - (44.19 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0004 - Staff Room Annexe - (11.07 SQM)	Office (2)	
B00B - R0005 - Home Base - (48.67 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0007 - Movement - (39.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Interview - (13.41 SQM)	Office (3)	
B00C - R0006 - General Learning Space - (53.71 SQM) - Teaching Space: 1	Student Space (57)	
B00C - R0007 - Home Base - (53.63 SQM) - Teaching Space: 1	Student Space (57)	
B00C - R0008 - Practical Activities - 1hb - (12.82 SQM)	Student Space (5)	
B00C - R0009 - Home Base - (53.71 SQM) - Teaching Space: 1	Student Space (57)	
B00C - R0011 - Movement - (58.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Kitchen - Type 1 - (84.49 SQM)	Student Space (100)	
B00F - R0001 - Laboratory L.S. - (88.53 SQM) - Teaching Space: 1	Student Space (63)	
B00F - R0002 - Preparation - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Room Annexe - (52.46 SQM)	Office (13)	
B00F - R0009 - Clerical Office/Workroom - (18.52 SQM)	Office (4)	
B00F - R0011 - Movement - (51.86 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Raised Platform - (50.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - General Learning Space - (39.24 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0014 - Dark Room - (8.3 SQM)	Office (2)	
B00G - R0006 - Materials Technology L.S. - (105.61 SQM) - Teaching Space: 1	Student Space (68)	
B00G - R0007 - Metal Technology Bay - (5.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Welding Area - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Practical Activities - (24.02 SQM)	Student Space (14)	
B00G - R0011 - Outdoor Workshop - (44.93 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Art Learning Space - (79.49 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R0012 - Reading Area - (172.04 SQM)	Student Space (35)	
B00H - R0013 - Special Programs Room - (25.86 SQM)	Student Space (24)	
B00H - R0014 - Movement - (68.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Canteen - (26.7 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Movement - (88.38 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Home Base - (59.91 SQM) - Teaching Space: 1	Student Space (35)	
B00N - R0001 - Outdoor Learning Area - (32.54 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Materials Technology L.S. - (32.6 SQM) - Teaching Space: 1	Student Space (18)	
OS 601 15902 - OS 601 15902 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (63)	