

SCHOOL:	Wellington High School (8197)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.















Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Computer Learning Space - (64.72 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0002 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (51)	
B00A - R0003 - Movement - (57.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (64)	
B00A - R0011 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0012 - General Learning Space - (49.61 SQM) - Teaching Space: 1	● Student Space (64)	
B00A - R0013 - General Learning Space - (49.45 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0015 - Staff Study - (23.81 SQM)	● Office (5)	
B00A - R0016 - Clinic - Girls - (11.78 SQM)	● Office (2)	
B00A - R0018 - Clinic - Boys - (11.79 SQM)	● Office (2)	
B00A - R0020 - Deputy Principal Office - (13.8 SQM)	● Office (3)	
B00A - R0021 - Interview/Office - Type 1 - (13.47 SQM)	● Office (3)	
B00A - R0022 - Principal Office - (18.04 SQM)	● Office (4)	
B00A - R0024 - Interview/Office - Type 1 - (14.88 SQM)	● Office (3)	
B00A - R0025 - Duplicating Workroom - (18.74 SQM)	● Office (4)	
B00A - R0027 - Administration - Clerical - (24.01 SQM)	● Office (6)	
B00A - R0031 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Staff Kitchen - (6.13 SQM)	● Office (1)	
B00A - R0040 - Commonroom - (43.25 SQM)	● Office (10)	
B00A - R0042 - Movement - (20.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Public Reception - (18.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Movement - (14.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Movement - (118.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - General Learning Space - S/P - (30.07 SQM) - Teaching Space: 1	● Student Space (53)	
B00A - R0052 - Practical Activities Area - 2 G.L.S. - (21.77 SQM)	● Student Space (43)	
B00A - R1001 - Computer Learning Space - (65.03 SQM) - Teaching Space: 1	● Student Space (63)	
B00A - R1002 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (64)	
B00A - R1007 - Staff Study - (24.85 SQM)	● Office (6)	
B00A - R1008 - General Learning Space - (49.91 SQM) - Teaching Space: 1	● Student Space (64)	
B00A - R1009 - General Learning Space - (49.98 SQM) - Teaching Space: 1	● Student Space (51)	
B00A - R1010 - Preparation - (24.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - General Learning Space - (76.29 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R1012 - General Learning Space - (50.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1013 - General Learning Space - (49.99 SQM) - Teaching Space: 1	● Student Space (48)	
B00A - R1015 - Staff Study - (40.28 SQM)	● Office (10)	
B00A - R1019 - Movement - (151.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Multi-Purpose Space - (458.13 SQM)	● Student Space (212)	
B00B - R0007 - Movement - (63.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Stage - (63.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Staff Kitchen - (14.15 SQM)	● Office (3)	
B00B - R0014 - Staff Study - (8.66 SQM)	● Office (2)	
B00C - R0005 - Staff Study - (39.25 SQM)	● Office (9)	
B00C - R0006 - Laboratory L.S. - (93.01 SQM) - Teaching Space: 1	● Student Space (102)	
B00C - R0007 - Preparation - (28.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Preparation - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Materials Technology L.S. - (101.98 SQM) - Teaching Space: 1	● Student Space (56)	
B00C - R0022 - Movement - (10.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Music Learning Space - (52.83 SQM) - Teaching Space: 1	● Student Space (52)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1005 - Art Learning Space - (111.5 SQM) - Teaching Space: 1	 Student Space (142)	
B00C - R1008 - Workshop - (12.58 SQM)	 Student Space (24)	
B00C - R1010 - Art Learning Space - (51.96 SQM) - Teaching Space: 1	 Student Space (65)	
B00C - R1011 - Staff Study - (12.73 SQM)	 Office (3)	
B00C - R1013 - Darkroom Space - (8.56 SQM)	 Office (2)	
B00C - R1014 - Movement - (77.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (55.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Student Canteen - (39.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Special Learning Space - (62.17 SQM) - Teaching Space: 1	 Student Space (78)	
B00E - R0006 - Materials Technology L.S. - (103.21 SQM) - Teaching Space: 1	 Student Space (56)	
B00E - R0010 - Design L.S. - (78.61 SQM) - Teaching Space: 1	 Student Space (43)	
B00E - R0011 - Movement - (67.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Staff Study - (18.59 SQM)	 Office (4)	
B00E - R0017 - Workshop Area - (139.8 SQM)	 Student Space (106)	
B00F - R0003 - Materials Technology L.S. - (90.82 SQM) - Teaching Space: 1	 Student Space (50)	
B00F - R0005 - Food/Research Space - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Food Technology L.S. - (139.14 SQM) - Teaching Space: 1	 Student Space (174)	
B00F - R0009 - Movement - (51.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Staff Study - (19.83 SQM)	 Office (4)	
B00G - R0001 - Laboratory L.S. - (93.16 SQM) - Teaching Space: 1	 Student Space (52)	
B00G - R0002 - Preparation - (48.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Laboratory L.S. - (91.87 SQM) - Teaching Space: 1	 Student Space (50)	
B00G - R0008 - Staff Study - (59.06 SQM)	 Office (14)	
B00G - R0009 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Seminar - (12.54 SQM)	 Office (3)	
B00G - R1006 - Audio Visual Workroom - (12.87 SQM)	 Student Space (6)	
B00G - R1007 - Seminar - (12.83 SQM)	 Office (3)	
B00G - R1008 - Seminar - (12.79 SQM)	 Office (3)	
B00G - R1009 - Main Area - (243.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Seminar - (19.85 SQM)	 Office (4)	
B00G - R1012 - Movement - (19.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - General Assistants - (49.95 SQM)	 Office (12)	
B00O - R0001 - Gymnasium - (86.34 SQM)	 Student Space (30)	
B00Q - R0003 - Administration - Clerical - (12.05 SQM)	 Office (3)	
B00Q - R0005 - General Learning Space - (47.7 SQM) - Teaching Space: 1	 Student Space (22)	