

SCHOOL:	Yanco Agricultural High School (8144)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Leeton

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.






































Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Commonroom - (58.03 SQM)	Office (14)	
B00A - R0003 - Public Entry - (75.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Administration - Clerical - (58.18 SQM)	Office (14)	
B00A - R0009 - Principal Office - (33.86 SQM)	Office (8)	
B00A - R0010 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Administration - Clerical - (39.61 SQM)	Office (9)	
B00A - R0012 - Movement - (75.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Administration - Clerical - (28.68 SQM)	Office (7)	
B00A - R0017 - Movement - (18.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Commonroom - (26.17 SQM)	Office (6)	
B00A - R0019 - Duplicating Workroom - (17.42 SQM)	Office (4)	
B00A - R0020 - Commonroom - (80.77 SQM)	Office (20)	
B00A - R0021 - Administration - Clerical - (27.32 SQM)	Office (6)	
B00A - R0023 - Movement - (34.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Duplicating Workroom - (16.34 SQM)	Office (4)	
B00A - R0028 - Commonroom - (49.27 SQM)	Office (12)	
B00A - R0029 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (123.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Dormitory - (14.89 SQM)	Office (3)	
B00A - R1004 - Movement - (57.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Movement - (10.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Study Space - (24.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Dormitory - (9.17 SQM)	Office (2)	
B00A - R1012 - Dormitory - (9.16 SQM)	Office (2)	
B00A - R1013 - Dormitory - (18.68 SQM)	Office (4)	
B00A - R1014 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Movement - (32.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Movement - (10.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Laboratory L.S. - (91.62 SQM) - Teaching Space: 1	Student Space (50)	
B00B - R0009 - Laboratory L.S. - (91.61 SQM) - Teaching Space: 1	Student Space (50)	
B00B - R0010 - Staff Study - (58.69 SQM)	Office (14)	
B00B - R0011 - Preparation - (43.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Workroom - (13 SQM)	Office (3)	
B00B - R1007 - Workroom - (12.85 SQM)	Office (3)	
B00B - R1008 - Workroom - (12.96 SQM)	Office (3)	
B00B - R1009 - Main Area - (189.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Audio Visual Workroom - (5.91 SQM)	Student Space (2)	
B00B - R1013 - Workroom - (53.22 SQM)	Office (13)	
B00C - R0015 - Clinic - Boys - (30.95 SQM)	Office (7)	
B00C - R0016 - Clinic - Girls - (31.05 SQM)	Office (7)	
B00C - R0018 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (14.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Clinic-Waiting - (9.88 SQM)	Office (2)	
B00C - R0023 - Clinic-Waiting - (17.38 SQM)	Office (4)	
B00C - R0028 - Clinic - (19.66 SQM)	Office (4)	
B00C - R0029 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0030 - Clinic - (28.95 SQM)	Office (7)	
B00C - R0031 - Interview/Meeting - (9.49 SQM)	Office (2)	
B00C - R0034 - Staff Kitchen - (11.18 SQM)	Office (2)	
B00C - R0037 - Clinic - (10.97 SQM)	Office (2)	
B00D - R0004 - Dormitory - (66.83 SQM)	Office (16)	
B00D - R0005 - Dormitory - (69.93 SQM)	Office (17)	
B00D - R0006 - Dormitory - (72.13 SQM)	Office (18)	
B00D - R0015 - Staff Study - (12.78 SQM)	Office (3)	
B00D - R0016 - Staff Study - (24.8 SQM)	Office (6)	
B00D - R0020 - Interview/Office - Type 1 - (19.37 SQM)	Office (4)	
B00D - R0021 - Seminar/Technology Space - (38.9 SQM)	Office (9)	
B00D - R0026 - Administration - Clerical - (26.5 SQM)	Office (6)	
B00D - R0029 - Movement - (65.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Movement - (113.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Dormitory - (12.22 SQM)	Office (3)	
B00D - R1002 - Dormitory - (18.76 SQM)	Office (4)	
B00D - R1003 - Dormitory - (69.23 SQM)	Office (17)	
B00D - R1004 - Dormitory - (67.95 SQM)	Office (16)	
B00D - R1005 - Dormitory - (67.93 SQM)	Office (16)	
B00D - R1006 - Dormitory - (69.01 SQM)	Office (17)	
B00D - R1007 - Dormitory - (20.07 SQM)	Office (5)	
B00D - R1008 - Dormitory - (10.77 SQM)	Office (2)	
B00D - R1009 - Dormitory - (20.34 SQM)	Office (5)	
B00D - R1010 - Dormitory - (60 SQM)	Office (15)	
B00D - R1011 - Dormitory - (59.85 SQM)	Office (14)	
B00D - R1020 - Movement - (214.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R1025 - Dormitory - (31.24 SQM)	Office (7)	
B00D - R1026 - Movement - (11.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Movement - (21.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (16.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Dormitory - (8.87 SQM)	Office (2)	
B00E - R0010 - Dormitory - (64.84 SQM)	Office (16)	
B00E - R0017 - Dormitory - (65.55 SQM)	Office (16)	
B00E - R0018 - Dormitory - (7.91 SQM)	Office (1)	
B00E - R0019 - Dormitory - (65.26 SQM)	Office (16)	
B00E - R0020 - Dormitory - (8.02 SQM)	Office (2)	
B00E - R0024 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Movement - (147 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Movement - (7.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Dormitory - (65.52 SQM)	Office (16)	
B00E - R1008 - Dormitory - (8.35 SQM)	Office (2)	
B00E - R1015 - Dormitory - (8.11 SQM)	Office (2)	
B00E - R1016 - Dormitory - (65.53 SQM)	Office (16)	
B00E - R1017 - Dormitory - (65.32 SQM)	Office (16)	
B00E - R1018 - Dormitory - (8.28 SQM)	Office (2)	
B00E - R1019 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1020 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R1022 - Movement - (141.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - General Learning Space - (55.36 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0005 - General Learning Space - (55.38 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0006 - General Learning Space - (55.36 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0007 - General Learning Space - (55.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0013 - General Learning Space - (93.7 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R0016 - Staff Study - (13.78 SQM)	○ Office (3)	
B00F - R0017 - Movement - (9.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (130.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (147.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - General Learning Space - (56.07 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R1003 - General Learning Space - (55.86 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1004 - General Learning Space - (55.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1005 - General Learning Space - (56.78 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R1006 - Staff Study - (14.63 SQM)	○ Office (3)	
B00F - R1007 - Staff Study - (16.65 SQM)	○ Office (4)	
B00F - R1008 - Computer Learning Space - (56.85 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R1009 - Staff Study - (36.87 SQM)	○ Office (9)	
B00F - R1012 - Staff Study - (14.25 SQM)	○ Office (3)	
B00G - R0001 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (15.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Dormitory - (8.64 SQM)	○ Office (2)	
B00G - R0013 - Dormitory - (65.09 SQM)	○ Office (16)	
B00G - R0020 - Dormitory - (65.11 SQM)	○ Office (16)	
B00G - R0021 - Dormitory - (8.37 SQM)	○ Office (2)	
B00G - R0022 - Dormitory - (64.61 SQM)	○ Office (16)	
B00G - R0023 - Dormitory - (8.99 SQM)	○ Office (2)	
B00G - R0028 - Movement - (13.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Movement - (150.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Movement - (7.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R1008 - Dormitory - (8.26 SQM)	○ Office (2)	
B00G - R1009 - Dormitory - (65.36 SQM)	○ Office (16)	
B00G - R1016 - Dormitory - (65.21 SQM)	○ Office (16)	
B00G - R1017 - Dormitory - (8.33 SQM)	○ Office (2)	
B00G - R1018 - Dormitory - (65.55 SQM)	○ Office (16)	
B00G - R1019 - Dormitory - (8.25 SQM)	○ Office (2)	
B00G - R1020 - Movement - (147.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R1021 - Movement - (9.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Multi-Purpose Space - (214.61 SQM)	● Student Space (99)	
B00H - R0004 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (6.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Stage - (56.68 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - General Learning Space - (54.41 SQM) - Teaching Space: 1	● Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0010 - Art Learning Space - (63.84 SQM) - Teaching Space: 1	 Student Space (35)	
B00I - R0011 - Workshop - (49.36 SQM)	 Student Space (22)	
B00I - R0012 - Art Learning Space - (64 SQM) - Teaching Space: 1	 Student Space (35)	
B00I - R0013 - Darkroom Space - (28.77 SQM)	 Office (7)	
B00I - R0015 - Movement - (9.17 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Movement - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00I - R1004 - Practice/Seminar - (13.09 SQM)	 Student Space (6)	
B00I - R1005 - Practice/Seminar - (16.35 SQM)	 Student Space (7)	
B00I - R1006 - Music Learning Space - (77.95 SQM) - Teaching Space: 1	 Student Space (43)	
B00I - R1011 - Staff Study - (29.08 SQM)	 Office (7)	
B00I - R1013 - General Learning Space - (47.56 SQM) - Teaching Space: 1	 Student Space (26)	
B00I - R1014 - General Learning Space - (47.69 SQM) - Teaching Space: 1	 Student Space (26)	
B00I - R1015 - General Learning Space - (47.71 SQM) - Teaching Space: 1	 Student Space (26)	
B00I - R1016 - Staff Study - (31.15 SQM)	 Office (7)	
B00I - R1026 - Movement - (14.29 SQM)	Not Applicable	Circulation or storage space.
B00I - R1028 - Practice/Seminar - (7.1 SQM)	 Student Space (3)	
B00J - R0001 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Dormitory - (9.92 SQM)	 Office (2)	
B00J - R0015 - Dormitory - (10.63 SQM)	 Office (2)	
B00J - R0016 - Dormitory - (10.57 SQM)	 Office (2)	
B00J - R0017 - Dormitory - (10.73 SQM)	 Office (2)	
B00J - R0018 - Dormitory - (9.89 SQM)	 Office (2)	
B00J - R0019 - Dormitory - (10.71 SQM)	 Office (2)	
B00J - R0020 - Dormitory - (10.57 SQM)	 Office (2)	
B00J - R0021 - Dormitory - (10.63 SQM)	 Office (2)	
B00J - R0025 - Dormitory - (10.65 SQM)	 Office (2)	
B00J - R0026 - Dormitory - (10.56 SQM)	 Office (2)	
B00J - R0027 - Dormitory - (10.14 SQM)	 Office (2)	
B00J - R0028 - Dormitory - (10.54 SQM)	 Office (2)	
B00J - R0029 - Dormitory - (10.44 SQM)	 Office (2)	
B00J - R0030 - Dormitory - (10.77 SQM)	 Office (2)	
B00J - R0031 - Dormitory - (10.08 SQM)	 Office (2)	
B00J - R0035 - Movement - (65.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0055 - Movement - (21.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0056 - Movement - (10.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0057 - Movement - (22.49 SQM)	Not Applicable	Circulation or storage space.
B00J - R0058 - Staff Kitchen - (13.39 SQM)	 Office (3)	
B00J - R0059 - Staff Lounge - (39.97 SQM)	 Office (9)	
B00J - R0061 - Movement - (40.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R1014 - Movement - (32.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R1015 - Dormitory - (10.85 SQM)	 Office (2)	
B00J - R1017 - Dormitory - (10.04 SQM)	 Office (2)	
B00J - R1018 - Dormitory - (10.62 SQM)	 Office (2)	
B00J - R1019 - Dormitory - (10.63 SQM)	 Office (2)	
B00J - R1020 - Dormitory - (10.63 SQM)	 Office (2)	
B00J - R1021 - Dormitory - (10 SQM)	 Office (2)	
B00J - R1022 - Dormitory - (10.66 SQM)	 Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1023 - Dormitory - (10.71 SQM)	Office (2)	
B00J - R1024 - Dormitory - (10.76 SQM)	Office (2)	
B00J - R1025 - Dormitory - (10.69 SQM)	Office (2)	
B00J - R1027 - Dormitory - (10.76 SQM)	Office (2)	
B00J - R1028 - Dormitory - (10.66 SQM)	Office (2)	
B00J - R1029 - Dormitory - (10.65 SQM)	Office (2)	
B00J - R1030 - Dormitory - (10.16 SQM)	Office (2)	
B00J - R1031 - Dormitory - (10.72 SQM)	Office (2)	
B00J - R1032 - Dormitory - (10.71 SQM)	Office (2)	
B00J - R1033 - Dormitory - (10.66 SQM)	Office (2)	
B00J - R1034 - Dormitory - (10.04 SQM)	Office (2)	
B00J - R1035 - Movement - (159.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R2014 - Movement - (33.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R2015 - Dormitory - (20.03 SQM)	Office (5)	
B00J - R2017 - Dormitory - (13.68 SQM)	Office (3)	
B00J - R2018 - Dormitory - (10.22 SQM)	Office (2)	
B00J - R2019 - Dormitory - (10.63 SQM)	Office (2)	
B00J - R2020 - Dormitory - (10.73 SQM)	Office (2)	
B00J - R2021 - Dormitory - (10.64 SQM)	Office (2)	
B00J - R2022 - Dormitory - (10.05 SQM)	Office (2)	
B00J - R2023 - Dormitory - (10.65 SQM)	Office (2)	
B00J - R2024 - Dormitory - (10.71 SQM)	Office (2)	
B00J - R2025 - Dormitory - (10.78 SQM)	Office (2)	
B00J - R2026 - Dormitory - (10.63 SQM)	Office (2)	
B00J - R2028 - Dormitory - (10.69 SQM)	Office (2)	
B00J - R2029 - Dormitory - (10.75 SQM)	Office (2)	
B00J - R2030 - Dormitory - (10.62 SQM)	Office (2)	
B00J - R2031 - Dormitory - (10.08 SQM)	Office (2)	
B00J - R2032 - Dormitory - (10.78 SQM)	Office (2)	
B00J - R2033 - Dormitory - (10.74 SQM)	Office (2)	
B00J - R2034 - Dormitory - (10.72 SQM)	Office (2)	
B00J - R2035 - Dormitory - (10.16 SQM)	Office (2)	
B00J - R2036 - Movement - (154.6 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Staff Lounge - (26.24 SQM)	Office (6)	
B00K - R0003 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Staff Study - (26.59 SQM)	Office (6)	
B00L - R0002 - Staff Lounge - (11.72 SQM)	Office (2)	
B00L - R0007 - Staff Lounge - (36.08 SQM)	Office (9)	
B00M - R0002 - Materials Technology L.S. - (85.22 SQM) - Teaching Space: 1	Student Space (47)	
B00M - R0008 - Design/Technology L.S. - (81.26 SQM) - Teaching Space: 1	Student Space (44)	
B00M - R0009 - Design/Technology L.S. - (81.08 SQM) - Teaching Space: 1	Student Space (44)	
B00M - R0013 - Staff Study - (17.46 SQM)	Office (4)	
B00M - R0016 - Hospitality Space - (81.7 SQM)	Student Space (37)	
B00M - R0017 - Food Technology L.S. - (115.66 SQM) - Teaching Space: 1	Student Space (64)	
B00M - R0023 - Preparation - Materials - (13.36 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Workshop - (129.22 SQM)	Student Space (59)	
B00N - R0008 - Movement - (9.21 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0009 - Movement - (20.66 SQM)	Not Applicable	Circulation or storage space.
B00N - R0014 - Metal Technology Bay - (159.58 SQM)	Not Applicable	Circulation or storage space.
B00N - R0015 - Welding Area - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00N - R0018 - Metal Technology Bay - (99.76 SQM)	Not Applicable	Circulation or storage space.
B00O - R0003 - Staff Kitchen - (7.15 SQM)	Office (1)	
B00O - R0006 - Movement - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00O - R0008 - Commonroom - (81.64 SQM)	Office (20)	
B00P - R0002 - Canteen - (16.04 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Interview/Office - Type 1 - (21.79 SQM)	Office (5)	
B00Q - R0002 - Dormitory - (43.05 SQM)	Office (10)	
B00Q - R0003 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R0004 - Dormitory - (12.15 SQM)	Office (3)	
B00Q - R0005 - Dormitory - (12.15 SQM)	Office (3)	
B00Q - R0006 - Dormitory - (12.12 SQM)	Office (3)	
B00Q - R0007 - Dormitory - (12.15 SQM)	Office (3)	
B00Q - R0008 - Dormitory - (12.12 SQM)	Office (3)	
B00Q - R0009 - Dormitory - (12.12 SQM)	Office (3)	
B00Q - R0010 - Dormitory - (12.08 SQM)	Office (3)	
B00Q - R0011 - Dormitory - (12.12 SQM)	Office (3)	
B00Q - R0016 - Dormitory - (43.1 SQM)	Office (10)	
B00Q - R0017 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R0018 - Dormitory - (9.51 SQM)	Office (2)	
B00Q - R0019 - Dormitory - (43.16 SQM)	Office (10)	
B00Q - R0022 - Dormitory - (18.89 SQM)	Office (4)	
B00Q - R0025 - Dormitory - (43.16 SQM)	Office (10)	
B00Q - R0026 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R0027 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R0028 - Dormitory - (43 SQM)	Office (10)	
B00Q - R0038 - Dormitory - (43.07 SQM)	Office (10)	
B00Q - R0039 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R0041 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0042 - Movement - (187.76 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1002 - Dormitory - (12.05 SQM)	Office (3)	
B00Q - R1003 - Dormitory - (12.08 SQM)	Office (3)	
B00Q - R1004 - Dormitory - (12.08 SQM)	Office (3)	
B00Q - R1005 - Dormitory - (12.11 SQM)	Office (3)	
B00Q - R1006 - Dormitory - (12.12 SQM)	Office (3)	
B00Q - R1007 - Dormitory - (12.15 SQM)	Office (3)	
B00Q - R1008 - Dormitory - (12.11 SQM)	Office (3)	
B00Q - R1009 - Dormitory - (12.11 SQM)	Office (3)	
B00Q - R1010 - Dormitory - (12.15 SQM)	Office (3)	
B00Q - R1011 - Movement - (26.11 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1013 - Dormitory - (42.99 SQM)	Office (10)	
B00Q - R1014 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R1015 - Dormitory - (43.1 SQM)	Office (10)	
B00Q - R1016 - Dormitory - (9.52 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R1017 - Dormitory - (18.8 SQM)	Office (4)	
B00Q - R1022 - Dormitory - (43.04 SQM)	Office (10)	
B00Q - R1023 - Dormitory - (9.55 SQM)	Office (2)	
B00Q - R1024 - Dormitory - (9.48 SQM)	Office (2)	
B00Q - R1025 - Dormitory - (43.01 SQM)	Office (10)	
B00Q - R1036 - Dormitory - (43.29 SQM)	Office (10)	
B00Q - R1037 - Dormitory - (9.52 SQM)	Office (2)	
B00Q - R1038 - Dormitory - (9.56 SQM)	Office (2)	
B00Q - R1039 - Dormitory - (43.09 SQM)	Office (10)	
B00Q - R1040 - Movement - (179.53 SQM)	Not Applicable	Circulation or storage space.
B00T - R0004 - Administration - Clerical - (11.86 SQM)	Office (2)	
B00U - R0001 - Gymnasium - (252.52 SQM)	Student Space (117)	
B00U - R0003 - Staff Study - (21.74 SQM)	Office (5)	
B00U - R0007 - Gymnasium - (76.87 SQM)	Student Space (35)	
BOAA - R0002 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
BOAB - R0001 - Workshop Area - (110.24 SQM)	Student Space (51)	
BOAJ - R0001 - Staff Study - (11.62 SQM)	Office (2)	
BOAO - R0006 - Staff Kitchen - (17.35 SQM)	Office (4)	
BOAT - R0003 - Movement - (8.88 SQM)	Not Applicable	Circulation or storage space.
NS 030 11864 - NS 030 11864 - Library - Primary/Audio Visual/Office - (171 SQM)	Student Space (79)	
NS 030 17907 - NS 030 17907 - Library - Primary/Audio Visual/Office - (171 SQM)	Student Space (79)	
NS 350 11746 - NS 350 11746 - Dormitory Toilet/Shower - (76 SQM)	Office (19)	
NS 350 11747 - NS 350 11747 - Dormitory Toilet/Shower - (76 SQM)	Office (19)	
NS 350 11748 - NS 350 11748 - Dormitory Toilet/Shower - (76 SQM)	Office (19)	
OS 720 12279 - OS 720 12279 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 903 16177 - OS 903 16177 - Dormitory - Teacher Accommodation. - (76 SQM)	Office (19)	
OS 903 16178 - OS 903 16178 - Dormitory - Teacher Accommodation. - (76 SQM)	Office (19)	
OS 903 16179 - OS 903 16179 - Dormitory - Teacher Accommodation. - (76 SQM)	Office (19)	
OS 903 16180 - OS 903 16180 - Dormitory - Teacher Accommodation. - (76 SQM)	Office (19)	